



PLANNING COMMISSION
DATE: 9/8/14
AGENDA ITEM: 4A – PUBLIC HEARING ITEM
CASE # 2014-43

ITEM: Village Park Preserve Residential Subdivision – Preliminary Plat

SUBMITTED BY: Nick Johnson, City Planner

REVIEWED BY: Kyle Klatt, Community Development Director
Jack Griffin, City Engineer
Brett Emmons, Emmons & Olivier Resources, Inc.
Greg Malmquist, Fire Chief
Stephen Mastey, Landscape Architecture, Inc.
Ann Pung-Terwedo, Washington County
John Hanson, Valley Branch Watershed District
Neil Ralston, Metropolitan Airports Commission

SUMMARY AND ACTION REQUESTED:

The Planning Commission is being asked to hold a public hearing to consider a Preliminary Plat request from GWSA Land Development, LLC for a 104-unit single family residential subdivision to be located on approximately 64 acres immediately west of Manning Avenue (CSAH 15) and immediately north of 30th Street within the southern portion of the Village Planning Area. Staff is recommending approval of the request subject to compliance with 13 conditions as noted in this report.

GENERAL INFORMATION

Applicant: GWSA Land Development, LLC (Craig Allen); 10850 Old County Road 15, Suite 200, Plymouth, MN 55441

Property Owners: Schiltgen Farms, Inc.; 10880 Stillwater Blvd. N., Lake Elmo, MN 55042 and Mark Holliday; PO Box 243, Lake Elmo, MN 55042

Location: Part of Sections 13, Township 29 North, Range 21 West in Lake Elmo, north of 30th Street and immediately west of Manning Avenue (CSAH 15). PID Numbers: 13.029.21.43.0004 and 13.029.21.44.0002.

Request: Application for preliminary plat approval of a 104-unit single family residential subdivision to be named Village Park Preserve.

Existing Land Use: Agriculture

Existing Zoning: RT – Rural Transitional Zoning

Surrounding Land Use: North – vacant/agricultural land, planned for Easton Village single family residential subdivision; west – Reid Park and Rural Single Family

	parcels; south – Heritage Farm open space preservation (OP) subdivision; east – Lake Elmo Airport.
<i>Surrounding Zoning:</i>	RT – Rural Development Transitional; OP – Open Space Preservation; PF – Public Facilities
<i>Comprehensive Plan:</i>	Village Urban Low Density Residential (1.5 – 2.49 units per acre) and Rural Area Development – City has submitted a Comprehensive Plan Amendment to the Metropolitan Council to change the land use guidance of the Holliday parcel from Rural Area Development to Village Urban Low Density Residential.
<i>Proposed Zoning:</i>	LDR – Urban Low Density Residential
<i>History:</i>	The subject properties are included in Village Planning Area boundary and municipal sewer service area as defined in the 2013 Village Land Use Plan. Site has historically been used for farming activities, including the growing of agricultural crops. The Sketch Plan was reviewed by the Planning Commission on 6/30/14. The Comprehensive Plan Amendment for the Holliday parcel was reviewed by the Planning Commission on 6/30/14. Both Land Use Applications were reviewed by the City Council on 7/15/14, where the CPA was approved (Resolution 2014-60)
<i>Deadline for Action:</i>	Application Complete – 8/14/2014 60 Day Deadline – 10/12/2014 Extension Letter Mailed – No 120 Day Deadline – 12/11/14
<i>Applicable Regulations:</i>	Chapter 153 – Subdivision Regulations Article 10 – Urban Residential Districts (LDR) §150.270 Storm Water, Erosion, and Sediment

REQUEST DETAILS

The City of Lake Elmo has received a request from GWSA Land Development, LLC for a preliminary plat to subdivide approximately 64 acres of land located within the Village Planning Area into 104 single family lots. The proposed plat would be located on property currently owned by Schiltgen Farms, Inc. and Mark Holliday, and would be located immediately west of Manning Avenue North (CSAH 15) and immediately north of 30th Street North. The two subject parcels have historically been used for agricultural purposes.

The preliminary plat has been developed in response to the City's Comprehensive Plan, which guides the property owned by Schiltgen Farms, Inc. for Village Urban Low Density Residential (V-LDR) development. It should be noted that the Holliday parcel is currently guided Rural Area Development (RAD). However, the City approved a Comprehensive Plan Amendment request to change the Holliday parcel from RAD to V-LDR on July 15, 2014 (Resolution 2014-60). The Comprehensive Plan Amendment request has progressed through adjacent jurisdiction review period, and the CPA application has been submitted to the Metropolitan Council. If approved, the proposed plat would be consistent with the Comprehensive Plan. The plat is designed to incorporate 104 single family lots, all of which are designed with minimum widths of 65 feet.

In terms of access, the preliminary plat shows a connection to 30th Street via the Village Parkway minor collector road in the southern portion of the plat. As shown on the proposed plat, the Village

Parkway minor collector road will serve as the primary access and circulation route for the development, extending from 30th Street in the south to the Easton Village residential subdivision in the north. In addition to the 30th Street connection, the proposed neighborhood would also benefit from temporary access to Manning Avenue (CSAH 15) through the southeast portion of Easton Village. However, this access will be closed off at some point the future. Therefore, Village Parkway, with connection to 30th Street and eventually Trunk Highway 5 (TH 5) to the north will serve as the primary access.

The proposed Village Park Preserve subdivision is the third subdivision in the Village Planning Area to submit Preliminary Plans. In terms of utilities, the subject parcels have access to City watermain within the 30th Street right-of-way north of Heritage Farms, as well as at the sanitary sewer lift station site immediately east of Reid Park. Existing sanitary sewer facilities are also located at the lift station site and will need to be extended to the subdivision to serve the residential development. As proposed, both the sewer and water services enter the subdivision in the southwestern portion of the development. Watermain is also extended to the existing watermain in 30th Street, providing a hydrological loop.

The proposed subdivision also includes a series of outlots that will provide for storm water management, open space, trails and a significant expansion of Reid Park. It should be noted that all of the outlots that are planned for parkland or storm water use will be deeded to the City.

According to the project narrative, the applicant is proposing to construct homes within the subdivision in two phases, with each phase consisting of 50+ residential lots. In addition, the narrative notes that the site will be mass graded during the first phase of construction. The mass grading would include preparation of the streets and storm water facilities. As the site is relatively flat, it is the goal of the applicant to balance the site with as much on-site material as possible.

PLANNING AND ZONING ISSUES

According to the City's Comprehensive Plan, the Village Park Preserve site is guided for Village Urban Low Density (Schiltgen Farms parcel) and Rural Area Development (Holliday parcel). While presenting a Sketch Plan for the proposed development, the applicant applied for a Comprehensive Plan Amendment for the Holliday parcel to change the land use guidance from Rural Area Development (RAD) to Village Urban Low Density (V-LDR). The Comprehensive Plan Amendment was unanimously recommended for approval by the Planning Commission on 6/30/14 and unanimously approved by the City Council on 7/15/14. The Comprehensive Plan Amendment has since been submitted to the Metropolitan Council for consideration after undergoing adjacent jurisdictional review. In order for the applicant to apply for a Final Plat, the Comprehensive Plan Amendment must be approved by the Metropolitan Council in advance of any Final approvals by the City. In addition, the site will be required to be zoned LDR – Low Density Residential prior to Final Plat approval. The overall subdivision plan has therefore been prepared in order to comply with the standards for the LDR zoning district in terms of lot size, lot widths, building setbacks, and other design criteria. The applicant notes in the project narrative that no variances are being sought for the proposed subdivision.

The arrangement of lots and blocks generally follow a grid-like pattern with the Village Parkway minor collector road running north-south through the center of the subdivision. The eastern half of the subdivision has three east-west streets, while the western half has two east-west streets. The proposed spacing of the local roads that intersect with the minor collector road generally meet the recommended spacing of 330 feet for neighborhood collector roads. It should also be noted that the

proposed subdivision includes three “eyebrow” or mini cul-de-sacs, two of which are located in the northeast and northwest corners of the subdivision, while the third is located in the southern portion of the development with direct access to the minor collector road. All local streets have been designed to comply with the City’s current street standard with a 60-foot right-of-way and 28-foot wide street.

Sidewalks are planned on one side of all residential streets within the subdivision per the City standard. In addition, the Village Parkway minor collector road includes a 6-foot walk on the west side and an 8-foot bituminous trail on east side, which is consistent with the City’s typical section for the collector. Finally, a trail connection to the proposed expansion of Reid Park is planned in the southwest corner of the subdivision, providing direct access to recreational facilities.

A typical lot building plan (detail) is included as part of the attached subdivision packet, and each lot as depicted in the plans includes a description of the lot size, dimensions, and all required setbacks. All of the lots proposed meet the City’s minimum area requirement of 8,000 for single family lots in a LDR district, with the smallest lot (Lot 4, Block 3) proposed at 8,342 square feet. The largest lot in the development (Lot 7, Block 2) is proposed at 27,055 sq. ft. in size. The Project Narrative notes that the lots will average 11,421 square feet in size, which exceeds the minimum requirements by a fairly wide margin. As an overview of the proposed lots, 60 lots are designed at 65 feet in width with the rest designed at widths of 75 or 81 feet. Generally speaking, the smaller lots of the subdivision are located on the eastern side of the development, and the larger lots are located west of the collector within closer proximity to the proposed park area adjacent to Reid Park.

The following is a general summary of the subdivision design elements that have been proposed as part of the Village Park Preserve preliminary plat and plans:

Zoning and Site Information:

- Existing Zoning: RT – Rural Development Transitional District
- Proposed Zoning: LDR - Urban Low Density Residential
- Total Site Area: 63.6 acres
- Total Residential Units: 104
- Proposed Density (Net): 2.20 units/acre

Proposed Lot Dimensional Standards:

- Min. Lot Width: 65 ft.
- Lot Depth: 130 ft. typical
- Lot Area: 8,000 sq. ft. (8,342 min. proposed)
- Front Yard Setback: 25 ft.
- Side Yard Setback: 5 ft. to garage, 10 ft. to living space
- Rear Yard Setback: 20 ft.

Proposed Street Standards:

- ROW Width – Local: 60 ft. (per Subdivision Ordinance)
- Street Widths – Local: 28 ft. (per City standard)

The standards listed above are all in compliance with the applicable requirements from the City’s zoning and subdivision regulations. Based on Staff’s review of the preliminary plat, the applicant

has demonstrated compliance with all applicable code requirements at the level of detail that is required for a preliminary plat.

As with any new subdivision, the City Code requires that a portion of the plat be set aside for public park use. In this case, the applicant has indicated that the western portion of the subdivision adjacent to Reid Park will be dedicated to the City for this purpose. Dedication of the proposed parkland is supported by the Village Land Use Plan, as the land offers a significant expansion of Reid Park and is identified as ecologically sensitive land in the Village Alternative Urban Area-wide Review (AUAR), the adopted environmental review document for the Village Planning Area. As proposed, access to the park area will be provided via a trail connection in the southwestern portion of the development. As the internal trail connections to Reid Park have not yet been determined, additional work with the Park Commission to determine trail routing will be necessary once plans for the expansion area are further developed.

The Subdivision Ordinance requires 10% of the land in urban residential districts to be set aside as parkland, which in this case amount to 6.36 acres (10% of 63.6 acres of total land). The Preliminary Plat (PP-6) indicates that Outlot 2, the proposed park area adjacent to Reid Park, is 686,961 square feet, or 15.77 acres, which is 9.41 acres above the required amount. However, it should be noted that two wetland areas exist in the proposed parkland, the area of which would not be eligible to count toward dedication. Removing the wetland areas from the calculation results in a dedication amount of 15.37 acres. Based on the level of proposed dedication, it is clear that the amount of land provided would far exceed the required amount of dedication required under the Subdivision Ordinance. When the amount of parkland provided exceeds the amount required under the ordinance, it is not uncommon for the applicant to receive a credit for the amount above what is required. It should be noted that the applicant is working on two other residential subdivision in the Village Area. The first, Village Preserve, is a 97-unit single family residential subdivision on approximately 40 acres of land in the northern portion of the Village Planning Area that has received Preliminary Plat approval. The second planned residential subdivision is on land owned by Schiltgen Farms, Inc. across Lake Elmo Ave. (CSAH 17) from the Village Preserve residential subdivision. If provided with a credit for land dedication above and beyond the required amount, it stands to reason that the credit could be utilized for the other two residential projects in which the applicant is engaged. Staff has contacted the City Attorney to confirm that this type of credit can be utilized off-site and can be granted via an approved developers agreement with the City, and the City Attorney confirmed that it is possible and legal under state statutes. In this case, the parkland credit amount would result in 9.01 acres (15.37 acres provided – 6.36 acres required = 9.01 acres of credit).

REVIEW AND ANALYSIS

City Staff has reviewed the Village Park Preserve Preliminary Plat. In general, the proposed plat will meet all applicable City requirements for conditional approval, and any deficiencies or additional modifications that are needed are noted as part of the review record. In addition, the City has received a detailed list of comments from the City Engineer, the Fire Chief, the City's Landscape Consultant, Washington County and the Metropolitan Airports Commission, all of which are attached for consideration by the Commission.

In addition to the general comments that have been provided in the preceding sections of this report, Staff would like the Planning Commission to consider the following review comments as well:

- **Comprehensive Plan.** Based upon the City's approval of the requested Comprehensive Plan Amendment for the Holliday parcel, the proposed subdivision is consistent with the

Lake Elmo Comprehensive Plan for this area. The net density proposed for the development fall within the range allowed for the Village Urban Low Density (V-LDR) land use category (1.5-2.49 units/acre). However, before proceeding to Final Plat, the applicant must receive formal approval of the Comp Plan Amendment from the Metropolitan Council (Condition #1). Other aspects of the Comprehensive Plan relate to the Village Park Preserve subdivision as follows:

- **Density Calculation.** The subject property is guided Village Urban Low Density Residential (V-LDR) in the Comprehensive Plan, which allows for a density range of 1.5-2.49 units/acre (net). The applicants have completed the density calculation using the methodology consistent with the City's adopted practice. The resulting net density calculation resulted in a net density of 2.20 units/acre (104 units/47.38 net developable acres). Therefore, the proposed subdivision is consistent with the density requirements of the Village Urban Low Density Residential land use category.
- **Parks.** The City's Park Plan identifies proposed location for neighborhood parks based on the anticipated population that should be served by each park, the location of existing City parks and areas that are currently underserved. Given the proximity of the subject parcels to Reid Park, the Park Plan does not call for a neighborhood park in this portion of the Village Planning Area. However, it should be noted that the Village Land Use Plan encourages the dedication of the land east of Reid Park as a park expansion. In March of 2014, Gonyea Development presented plans for the Village Preserve subdivision in the northern portion of the Village Planning Area to the Park Commission. As part of the broader review of the area, Gonyea presented their plan to expand Reid Park as part of the Village Park Preserve subdivision. The Park Commission was supportive of this approach, as it would allow for the creation of a destination park in the Village. As part of the Village Park Preserve subdivision, the applicants are proposing to dedicate 15.77 acres of land for the expansion of Reid Park. Therefore, the Reid Park expansion would be consistent with the Village Land Use Plan and has been supported by the City's Park Commission.
- **Water.** Water will be provided to this area via existing watermain along 30th Street. In addition, the applicant proposes to pull watermain from the lift station, creating a hydrological loop of the system. It should be noted that the City has more than adequate capacity to serve the future subdivision on the subject property as a result of the construction of Well #4. Well #4 was recently connected to the broader water system as a result of a recent watermain extension north of the Village Planning Area.
- **Sanitary Sewer.** The Village Preserve subdivision will be served by the sanitary sewer extension from the existing facilities located at the Village lift station site to the west of the proposed development. All wastewater for the proposed development would be directed via forcemain to the Cottage Grove Ravine Interceptor located to the east of Lake Elmo Ave near Interstate-94, which is part of the regional wastewater treatment system administered by the Metropolitan

Council. It should be noted that there is adequate capacity of the wastewater system to serve the proposed residential development.

- **Phasing/Staging Plan.** According to the City's Wastewater Plan, the Village Planning Area is in Stage 1 of the City's planned service areas. Therefore, the proposed subdivision is consistent with the City's Staging Plan.
- **Zoning.** The proposed zoning for the Village Preserve site will be LDR – Low Density Residential. The submitted development plans demonstrate compliance with the City's urban residential zoning requirements. Single family detached housing is a permitted use within the LDR zoning district.
- **Subdivision Requirements.** The City's Subdivision Ordinance includes a fairly lengthy list of standards that must be met by all new subdivisions, and include requirements for blocks, lots, easements, erosion and sediment control, drainage systems, monuments, sanitary sewer and water facilities, streets, and other aspects of the plans. Staff, as well as the City Engineer, have not identified any existing conflicts with the City's Subdivision Ordinance.
- **Infrastructure.** The developer will be required to construct all streets, sewer, water, storm water facilities, and other infrastructure necessary to serve the development.
- **Phasing – Grading and Construction.** The applicant noted in the submitted Project Narrative (Attachment #2) that the subdivision will be split into two phases of construction with regards to residential. However, the applicant intends to mass grade the site as part of the first phase of construction. As part of Final Plat and final construction documents, more detailed plans with regards to phasing of all improvements will be required. The City Engineer has also requested additional detail related to the phasing of improvement for the next stage of City approval.
- **Wetlands.** The submitted narrative indicates that there are three wetland on the site. Two of the identified wetland are located within the proposed park area and will not be impacted by development activity. The third wetland, 782 square feet in size, is located on the Holliday parcel. The applicant has noted that this wetland is eligible for a de minimis exemption. The applicant is proposing to mitigate this smaller wetland through the Valley Branch Watershed District permitting process. Typical for any preliminary plat approval, the applicant will be required to meet all the rules and regulations of the Wetland Conservation Act and Valley Branch Watershed District (Condition #5).
- **Trails.** The applicants are proposing two segments of trails within the development. The first trail is contained within the Village Parkway minor collector road and is consistent with the City's approved typical section. The north-south trail segment will eventually provide direct pedestrian connection through Easton Village to the downtown area to the north and west. The second trail segment proposed is in the southwest portion of the development to provide connection to the proposed park expansion area next to Reid Park. Ultimately, staff would recommend that the Park Commission engage in a broader planning effort for the future use and design of Reid Park. Once a broader plan is

established, effective trail connections can be made to the existing park area to the west of the proposed development. In addition to the sidewalks proposed for the residential subdivision, there should be ample facilities and for walking, biking, and other recreational activities, offering effective connections to Reid Park and the broader Village Area.

- **Landscaping and Tree Preservation.** The landscape and tree preservation plans have been reviewed by the City's consulting landscape architect, Stephen Mastey. Mr. Mastey's review memorandum related to the landscape and tree preservation plans is found in Attachment #9. Mastey has requested additional calculations pertaining to street trees. In addition, he makes several recommendations related to native ground cover and other plant selections. Staff is recommending that the Final Landscape Plan be updated per the recommendations of the landscape consultant (Condition #9). In addition, it should be noted that the Tree Preservation information is located on the provided Tree Survey (TS1). As noted in the tree survey, the proposed removal amount of significant trees is 22.6%, which is under the 30% removal threshold permitted under the City's Tree Preservation Ordinance. Finally, with regards to tree preservation, the submitted landscape plans do not include tree protective fencing or other measures around the trees to be saved on the site. As part of the Final Landscape Plan, staff would recommend that tree protection measures be included.
- **Buffering.** Buffering for the proposed subdivision is applicable in two areas:
 - **Village Greenbelt.** As part of the Village Land Use Plan, the southern and eastern portions of the development are guided for a greenbelt to create separation of residential lots from 30th Street and Manning Avenue. As proposed in the Village Park Preserve Preliminary Plat, this area is currently being utilized for stormwater management purposes, which is allowed under the City's Land Use Plan. In addition, the Village Land Use Plan does not specify a set distance for the greenbelt. As shown in the plans, the separation between residential lots and 30th Street right-of-way ranges from 40 feet up to 130 feet. The separation between residential lots and Manning Avenue is greater. In addition, the Landscape Plan includes a more robust planting schedule along the greenbelt area for both Manning Avenue and 30th Street, including coniferous and evergreen trees for year-round screening. A cross section of the proposed plantings is also provided.
 - **Mcleod Property.** In addition to the recommended buffering along 30th Street and Manning Avenue, buffering and screening around the Mcleod property in the southwest portion of the development, particularly the east boundary, is required as a condition of approval for the Comprehensive Plan Amendment (Resolution 2014-60 – Attachment #4). Once again, a more aggressive planting schedule has been provided around the east and north boundary of the Mcleod property, providing year round screening. In addition, the lots on the east side of the Mcleod parcel are of greater size and depth than most of the lots in the development. Nevertheless, staff would recommend that the applicant install an additional row of trees in the rear of 1-3, Block 1 to provide additional screening.

Staff is recommending that this requirement be included as a condition of approval (Condition #11).

- **Streets.** The proposed street system has been designed to comply with all applicable subdivision requirements and City engineering standards. All of the proposed cul-de-sacs meeting the minimum turning radii specified under the Subdivision Ordinance. It should be noted that the City Engineer has recommended some modest changes related to the southernmost intersection of Street 2 and the minor collector road. This recommendation is included in as a requested modification in his report, to which staff is recommending be included as a condition of approval (Condition #3).
- **Secondary Access.** The primary access to the site will be provided from 30th Street via the Village Parkway minor collector road. Temporary secondary access may be achieved through the temporary connection to Manning Avenue (CSAH 15) through Easton Village. However, as this access is planned to be temporary, the permanent secondary access will be the connection of the Village Parkway minor collector road to Trunk Highway 5. The City must consider the timing of the closure of the temporary access on Manning Avenue with the broader interest of secondary access in mind. Coordination with both property owners/developers will continue in this regard.
- **Street Names.** Staff is recommending that the street names for the proposed subdivision follow the Washington County street naming system. Staff has provided the applicant with proposed street names that are consistent with the Washington County system. In conversation with the applicant, they are amenable to the provided street names. Staff will work with the applicant to incorporate the correct street names in advance of Final Plat.
- **City Engineer Review.** The City Engineer has provided the Planning Department with a detailed comment letter (Attachment #5) as a summary of his review of the Village Park Preserve Preliminary Plat. In addition, the City Engineer obtained additional review of the proposed storm water system through Brett Emmons of Emmons & Olivier Resources, Inc. In the memorandum, the Engineer highlights several of the critical path issues or modifications that must be resolved for the proposed design to move forward. One of these issues remains the discharge of storm water to a new location within a new culvert to the south of 30th Street. As a condition of approval (Condition #6), staff is recommending that the necessary permissions related to this stormwater discharge be provided in advance of Final Plat application. In addition, the other necessary revisions and modifications identified in the City Engineer's memorandum must also be made in advance of Final Plat (Condition #3).
- **Washington County Review.** County Staff has reviewed the Village Park Preserve plat and provided specific comments to the City in a letter dated September 3, 2014 (Attachment #7). The most significant of the County's comments relate to the need for additional right-of-way for both Manning Avenue (CSAH 15) and the Manning-30th Street intersection. As a condition of approval (Condition #8), staff is recommending that the applicants observe all requirements in the review memorandum submitted by Washington County.

- ***Watershed Districts.*** The project area lies within the Valley Branch Watershed District (VBWD). The Valley Branch Watershed District has not provided any formal comments for the proposed plat at this time. It should be noted that the developer must meet all the rules of the Wetland Conservation Act and VBWD and will need to secure permits from the VBWD in order to proceed with the development as planned (Condition #5).
- ***Fire Department Review.*** The Fire Chief has reviewed the plat (Attachment #6) and found the hydrant locations to be sufficient in terms of spacing and operation effectiveness. In addition, the Fire Chief is requesting that the street names follow the Washington County street naming system. Staff will work with the applicant to update the street names per the input of the Fire Chief in advance of Final Plat.
- ***Metropolitan Airports Commission Review.*** Neil Ralston of the Metropolitan Airports Commission (MAC) has submitted a review memorandum documenting the concerns and requests for additional work related to the subdivision's location adjacent to the Lake Elmo Airport. The memorandum is found in Attachment #8. The most critical issues relate to the design of the stormwater management facilities on the site. In addition, MAC is recommending that an aeronautical study be filed with the FAA for any structures over 35 feet in height utilized in the construction of the subdivision. Staff is recommending that the applicant address all review comments in the memorandum submitted by MAC as part of any final plat submittal (Condition #13).

Based on the above Staff report and analysis, Staff is recommending approval of the preliminary plat with 13 conditions intended to address the outstanding issues noted above and to further clarify the City's expectations in order for the developer to move forward with a final plat. The recommended conditions are as follows:

Recommended Conditions of Approval:

- 1) The Metropolitan Council must approve the Comprehensive Plan Amendment for the Holliday parcel in advance of the City's consideration of an application for Final Plat for the Village Park Preserve Subdivision.
- 2) In advance of Final Plat application, the applicant shall provide adequate title evidence satisfactory to the City Attorney.
- 3) All required modifications to the plans as requested by the City Engineer in a review memorandum dated September 4, 2014 shall be incorporated into the plans prior to consideration of a Final Plat.
- 4) The Preliminary Plat approval is conditioned upon the applicant meeting all minimum City standards and design requirements.
- 5) The developer shall follow all of the rules and regulations spelled out in the Wetland Conservation Act, and shall acquire the needed permits from Valley Branch Watershed District prior to the commencement of any grading or development activity on the site.

- 6) Related to the proposed storm water discharge to the south, the applicant must provide written permission from all property owners of the affected parcels located south of the proposed 30th Street culvert consenting to the discharge location, volume and rate(s) in advance of submitting Final Plat.
- 7) The applicant shall be responsible for the submission of final plans and the construction of all improvements within the 30th Street right-of-way as required by the City and further described in the review memorandum from the City Engineer dated September 4, 2014.
- 8) The applicant shall observe all right-of-way and other requirements included in a review memorandum from Washington County dated September 3, 2014.
- 9) The Landscape Plan shall be updated per the recommendations of the City's Landscape Consultant, describe in a memo dated September 4, 2014. Tree protection measures for trees intended to be saved according to the submitted Tree Survey must be included in the Final Landscape Plan.
- 10) The applicant must enter into a separate grading agreement with the City prior to the commencement of any grading activity in advance of final plat and plan approval. The City Engineer shall review any grading plan that is submitted in advance of a final plat, and said plan shall document extent of any proposed grading on the site.
- 11) The applicant shall install an additional row of trees in the rear of Lots 1-3, Block 1 to provide additional screening for the eastern boundary of the Mcleod property to satisfy the condition of approval related to the requested Comprehensive Plan Amendment.
- 12) The developer shall obtain all required permits from Northern Natural Gas to perform construction work over the gas line that runs from north to south across this site.
- 13) The developer shall address any comments from Metropolitan Airport Commission documented in a review memorandum dated September 3, 2014 as part of a final plat submission for any portion of Village Park Preserve.

DRAFT FINDINGS

Staff is recommending that the Planning Commission consider the following findings with regards to the proposed Village Park Preserve Preliminary Plat:

- That the Village Park Preserve Preliminary Plat is consistent with the Lake Elmo Comprehensive Plan and the Future Land Use Map for this area conditioned upon receiving final approval for the Metropolitan Council for the Comprehensive Plan Amendment for the Holliday parcel.
- That the Village Park Preserve Preliminary Plat complies with the City's LDR- Urban Low Density Residential zoning district.
- That the Village Park Preserve Preliminary Plat complies with the City's Subdivision Ordinance.

- That the Village Park Preserve Preliminary Plat meets other City zoning ordinances, such as landscaping, tree preservation, erosion and sediment control, and other ordinances, except where noted in the conditions of approval or the attachments to this report.
- That the Village Park Preserve Preliminary Plat is consistent with the City’s engineering standards provided the plans are updated to address the City Engineer’s comments documented in a letter dated September 4, 2014.
- That the Village Park Preserve Preliminary Plat provides effective and safe pedestrian facilities, providing access to Reid Park and a future connection to downtown Lake Elmo, contributing to a walkable community as guided by the Village Land Use Plan.
- That the Village Park Preserve Preliminary Plat provides a significant expansion of Reid Park, as recommended by the Village Land Use Plan.
- That the Village Park Preserve residential subdivision will allow for the completion of the Village Parkway minor collector road from 30th Street to Easton Village, providing a critical transportation improvement needed for the Village Planning Area.

RECOMMENDATION:

Staff recommends that the Planning Commission recommend approval of the Village Park Preserve Preliminary Plat with the 13 conditions of approval as listed in the Staff report.

Suggested motion:

“Move to recommend approval of the Village Park Preserve preliminary plat with the 13 conditions of approval as drafted by Staff based on the findings of fact listed in the Staff Report.”

ATTACHMENTS:

1. Location Map
2. Application Form and Project Narrative
3. Village Park Preserve Preliminary Plat and Plans (34 Sheets)
4. Resolution 2014-60
5. City Engineer Review Memorandum, dated 9/4/14
6. Fire Chief Review Memorandum, dated 8/27/14
7. Washington County Review Letter, dated 9/3/14
8. Metropolitan Airports Commission Review Letter, dated 9/3/14
9. City’s Landscape Consultant Review Memo, dated 9/4/14.

ORDER OF BUSINESS:

- Introduction.....Community Development Director
- Report by Staff..... City Planner
- Questions from the Commission..... Chair & Commission Members

- Open the Public HearingChair
- Close the Public Hearing.....Chair
- Discussion by the Commission.....Chair & Commission Members
- Action by the Commission..... Chair & Commission Members

Date Received: _____
Received By: _____
LU File #: _____



651-747-3900
3800 Laverne Avenue North
Lake Elmo, MN 55042

PRELIMINARY PLAT APPLICATION

~~XXXXXX~~ PARK PRESERVE
Village

Applicant: GWSA Land Development, LLC
Address: 10850 Old County Road 15, Suite 200, Plymouth, MN 55441
Phone #: 952-270-4473
Email Address: Craig@gsayencompany.com

Fee Owner: Mark Holliday
Address: PO Box 243, Lake Elmo, MN 55042
Phone #: 651-270-1318
Email Address: Markh85@aol.com

Property Location (Address and Complete (long) Legal Description): See Attached

General information of proposed subdivision: Preliminary Plat to incorporate +/- 14 acres with The Schiltgen Property as part of a 104 lot single family development

Conducted pre-application meeting with Staff? Yes No

In signing this application, I hereby acknowledge that I have read and fully understand the applicable provisions of the Zoning Ordinance and current administrative procedures. I further acknowledge the fee explanation as outlined in the application procedures and hereby agree to pay all statements received from the City pertaining to additional application expense.

Signature of applicant: [Signature] Date: 8/6/14

City Use Only Planning: Zoning District: _____ Date: _____ Reviewed by: _____ Date: _____ Subject to the following conditions: _____ Engineering: Reviewed by: _____ Date: _____ Subject to the following conditions: _____



Lake Elmo City Hall
651-747-3900
3800 Laverne Avenue North
Lake Elmo, MN 55042

ACKNOWLEDGEMENT OF RESPONSIBILITY

This is to certify that I am making application for the described action by the City and that I am responsible for complying with all City requirements with regard to this request. This application should be processed in my name and I am the party whom the City should contact regarding any matter pertaining to this application.

I have read and understand the instructions supplied for processing this application. The documents and/or information I have submitted are true and correct to the best of my knowledge. I will keep myself informed of the deadlines for submission of material and of the progress of this application.

I understand that this application may be reviewed by City staff and consultants. I further understand that additional information, including, but not limited to, traffic analysis and expert testimony may be required for review of this application. I agree to pay to the City upon demand, expenses, determined by the City, that the City incurs in reviewing this application and shall provide an escrow deposit to the City in an amount to be determined by the City. Said expenses shall include, but are not limited to, staff time, engineering, legal expenses and other consultant expenses.

I agree to allow access by City personnel to the property for purposes of review of my application.

Signature of applicant  Date 8/6/14

Name of applicant CRAG ALLEN Phone 952-270 4493
(Please Print)

Name and address of Contact (if other than applicant) _____



Lake Elmo City Hall
651-747-3900
3800 Laverne Avenue North
Lake Elmo, MN 55042

AFFIRMATION OF SUFFICIENT INTEREST

I hereby affirm that I **am the fee title owner** of the below described property or that I have written authorization from the owner to pursue the described action.

Name of applicant Craig Auer, LWSA Land Development, LLC
(Please Print)

Street address/legal description of subject property See Attached

Craig Auer
Signature

8/6/14
Date

If you are not the fee owner, attach another copy of this form which has been completed by the fee owner or a copy of your authorization to pursue this action.

If a corporation is fee title holder, attach a copy of the resolution of the Board of Directors authorizing this action.

If a joint venture or partnership is the fee owner, attach a copy of agreement authorizing this action on behalf of the joint venture or partnership.



Lake Elmo City Hall
651-747-3900
3800 Laverne Avenue North
Lake Elmo, MN 55042

AFFIRMATION OF SUFFICIENT INTEREST

I hereby affirm that I am the fee title owner of the below described property or that I have written authorization from the owner to pursue the described action.

Name of applicant PETER J. SCHULTZ
(Please Print)

Street address/legal description of subject property _____

Peter J. Schultz 8-19-14
Signature Date

If you are not the fee owner, attach another copy of this form which has been completed by the fee owner or a copy of your authorization to pursue this action.

If a corporation is fee title holder, attach a copy of the resolution of the Board of Directors authorizing this action.

If a joint venture or partnership is the fee owner, attach a copy of agreement authorizing this action on behalf of the joint venture or partnership.

Schiltgen Farms Property Description – Manning:

The land referred to in this Commitment is situated in the County of Washington, State of Minnesota, and is described as follows:

The North 50 acres of the South Half of the Southeast Quarter of Section 13, Township 29 North, Range 21 West, Washington County, Minnesota, except that part which lies easterly of the following described line: Commencing at the southeast corner of said Southeast Quarter; thence South 88 degrees 45 minutes 30 seconds West along the South line of said Southeast Quarter, 159.73 feet (bearings are based on the Washington County Coordinate System); thence North 1 degree 14 minutes 30 seconds West, 33 feet, thence North 43 degrees 59 minutes 50 seconds East, 142.10 feet to the point of beginning of the line to be described; thence North 0 degrees 45 minutes 51 seconds West, 1188.14 feet to said North line of said South Half of the Southeast Quarter and said line there terminating.

Abstract Property.



Lake Elmo City Hall
651-747-3900
3800 Laverne Avenue North
Lake Elmo, MN 55042

AFFIRMATION OF SUFFICIENT INTEREST

I hereby affirm that I am the fee title owner of the below described property or that I have written authorization from the owner to pursue the described action.

Name of applicant MARK HOLLIDAY
(Please Print)

Street address/legal description of subject property See Attached

Mark Holliday
Signature

8-12-14
Date

If you are not the fee owner, attach another copy of this form which has been completed by the fee owner or a copy of your authorization to pursue this action.

If a corporation is fee title holder, attach a copy of the resolution of the Board of Directors authorizing this action.

If a joint venture or partnership is the fee owner, attach a copy of agreement authorizing this action on behalf of the joint venture or partnership.

Mark Holliday Property Description:

The land referred to in the Commitment is situated in Washington County, State of Minnesota and is described as follows:

The South 498.6 feet of the South Half of the Southeast Quarter (S1/2 of SE1/4); Section Thirteen (13), Township Twenty Nine North (29N.), Range Twenty-one West (21W.); except the West 1273.0 feet of the South Half of the Southeast Quarter of said Section Thirteen (13). And excepting therefrom that portion of the above tract conveyed to the County of Washington by that certain Quit Claim Deed dated March 30, 1987, and filed of record in the Office of the Washington County Recorder on April 2, 1987 as Document No. 535377.

Abstract Property.

VILLAGE PARK PRESERVE
Development Narrative
September 2, 2014

Developer Introduction:

GWSA LAND DEVELOPMENT, LLC.
Craig Allen
10850 Old County Road 15
Suite 200
Lake Elmo, Minnesota 55441
Telephone: 952-270-4473
Email: craig@gonyecompany.com

The developer is proposing a community of 104 single family homes on +/- 63.6 acres of land located on the west side of Manning Avenue North (CASH15), north of 30th Street North. The Schiltgen parcel and the Holliday parcel comprise the 63.6 acres of land. This proposed residential development will consist of higher end single family homes. It is anticipated that these homes will range in price from \$400,000 to \$650,000. The development is located in an area of Lake Elmo with easy access to the transportation system. This will provide the future home owners a secluded place to live that is located within minutes of all the amenities Lake Elmo has to offer with the regional facilities of the larger metropolitan area.



“VILLAGE PARK PRESERVE”

The project is anticipated to be constructed in two phases, of 50-60 lots per phase. The primary access is the proposed Village Parkway from 30th Street North. Over 15.7 acres of land is proposed to be dedicated as parkland to add to the existing Reid Park. A trail connection to the park area is proposed in the southwest corner. Over seventy five percent of the homes in the community will have a walkout basement. The project is located within the Stillwater School District #834.

Development Team:

Civil Engineering, Surveying & Land Planning

Sathre-Bergquist, Inc.

Robert S. Molstad, P.E.

David B. Pemberton, P.L.S.

150 South Broadway

Wayzata, Minnesota 55391

Telephone: 952-476-6000

Facsimile: 952-476-0104

Email: molstad@sathre.com

Email: pemberton@sathre.com

Wetland & Biological Sciences

Kjolhaug Environmental Services

Melissa Barrett

26105 Wild Rose Lane

Shorewood, MN 55331

Telephone: 952-401-8757

Email: Melissa@kjolhaugenv.com

Soil Sciences

Haugo GeoTechnical Services

Paul Haugo

13570 Grove Drive #278

Maple Grove, MN 55311

Telephone: (612) 554-4829

Email: p.haugo@gmail.com

Property Ownership:

Per Schedule A of Title Commitment No. HB-26627A (northerly property)

The North 50 acres of the South Half of the Southeast Quarter of Section 13, Township 29 North, Range 21 West, Washington County, Minnesota, except that part which lies easterly of the following described line:

Commencing at the southeast corner of said Southeast Quarter; thence South 88 degrees 45 minutes 30 seconds West along the South line of said Southeast Quarter, 159.73 feet (bearings are based on the Washington County Coordinate System); thence North 01 degree 14 minutes 30

seconds West, 33 feet, thence North 43 degrees 59 minutes 50 seconds East, 142.10 feet to the point of beginning of the line to be described; thence North 00 degrees 45 minutes 51 seconds West, 1188.14 feet to said North line of said South Half of the Southeast Quarter and said line there terminating.

Abstract Property.

Per Schedule A of Title Commitment No. HB-26880 (southerly property)

The South 498.6 feet of the South Half of the Southeast Quarter (S1/2 of SE1/4); Section Thirteen (13), Township Twenty Nine North (29N.), Range Twenty-one West (21W.); except the West 1273.0 feet of the South Half of the Southeast Quarter of said Section Thirteen (13). And excepting therefrom that portion of the above tract conveyed to the County of Washington by that certain Quit Claim Deed dated March 30, 1987, and filed of record in the Office of the Washington County Recorder on April 2, 1987 as Document No. 535377.
Abstract Property.

Comprehensive Plan, Zoning, Density, & Variances:

The site consists of the Schiltgen parcel +/- 49 acres and the Holliday parcel +/- 14.8 acres. The Existing Land Use is classified as Rural Area Development. On the Village Land Use Plan, the planned Land Use for the Schiltgen parcel is Village Urban Low Density (V-LDR) and Rural Area Development (RAD) for the Holliday parcel.

The attached preliminary plat shows 104 single family lots that are a minimum width of 65 feet. There are 60 lots that are in the 65' lot width, 4 lots in the 75' lot width, and 40 lots that are 81' in width. The smallest lot area is L4B3 (65') – 8,342 sf and the largest lot area is L7B2 (81') at 27,055 sf, with an average lot area of 11,421 for the entire project.

Lake Elmo Zoning:

Both parcels are currently zoned RT. The Schiltgen parcel is currently planned as Village Urban Low Density (V-LDR) and the Holliday parcel is currently planned as Rural Area Development (RAD). A Comprehensive Plan Amendment to change the Holliday parcel from RAD to V-LDR was approved by City Council and is currently being reviewed by the MET Council. The V-LDR district has the following requirements:

V-LDR District

1.5 – 2.5 units per acre

Minimum Lot Area – 8,000 square feet

Minimum Width – 60 feet

Front Yard Setback – 25 feet

Side Yard Setback – 5 feet to garage and 10 feet to living space

Corner Yard Setback – 15 feet

Rear Yard Setback – 20 feet

Density:

Gross Site Area: 63.55 acres

Gross Density = $104/63.55 = 1.64$ units per acre

Wetland Area: 0.40 acres

Proposed Park Area: 15.77 acres

Net Area: $63.55 - 0.40 - 15.77 = 47.38$ acres

Net Density = $104/47.38 = 2.2$ units per acre

Variances – No variances are proposed.

A preliminary plat lot area tabulation sheet is in Appendix A of this narrative.

Site Analysis:

The site is currently being used for agricultural purposes. Please refer to the ALTA Survey and the aerial photos. Utility service, sanitary sewer will be provided to the site as part of the proposed Trunk Sanitary Sewer project that will extend sewer service from the new lift station at Reid Park, north to the Site, the current plan is to provide sanitary sewer from the stub in the proposed Village Parkway, from the Easton Village project. A 12” trunk watermain will be installed with the proposed trunk sanitary sewer system, that will provide a watermain connection for the proposed development. Storm water will be managed and outlet from the site in accordance with the City and Watershed requirements. The proposed stormwater plan would outlet with a new storm sewer pipe down the west side of Manning Avenue North to the culvert about 850 feet south of 30th Street North. The site is within the Valley Branch Watershed District. Minor utilities (gas, electric, phone, and TV) will need to be extended to service the site.

The topography of the site is relatively flat on most of the site, 914 to 926 for the proposed development area. The proposed park area drops in elevation from 926 to +/- 892.

There are three existing wetlands on the site, two wetlands are within the proposed park area and no impacts are proposed by the residential development. The third wetland qualifies for a de minimis exemption and an application has been filed with Valley Branch Watershed District. Once approved the de minimis classification would allow us to fill without replacing.

The USDA Soil Survey of the project site indicates Antigo Silt Loams, Campia Silt Loams, and Mahtomedi Loamy Sand. The soils that are present consist of mostly moderately well drained loams and sandy loams with a moderate permeability.

Street Design:

“Village Park Preserve” proposes a north south parkway (Village Parkway), the parkway will be 32’ B-B within an 80’ ROW. The other public streets within the project would be 28’ B-B, with a sidewalk along one side of the street, within a 60’ ROW. The cul-de-sacs will have a 44’ Radius to the back of curb. All streets will be constructed to the City of Lake Elmo standard street section.

Utility Services:

City sanitary sewer and watermain will need to be extended to the site, please see the notes above.

Site Grading:

The site grading is planned to begin in the fall of 2014. The project will be graded in one phase. The overall graded area is +/- 45.5 acres. We are proposing to grade all streets to the proposed hold downs and prepare corrected building pads for all home sites. We are creating five stormwater ponding areas and one infiltration area to meet the stormwater treatment requirements of the City and the Watershed. The excavation of on-site material is estimated at +/- 180,000 cy. It is our design objective to balance the site with on-site material, some import of suitable structural fill material may be necessary for building pad, street, and retaining wall construction. As the final design analysis is completed we will provide detailed construction plans for the project to the City of Lake Elmo.

Stormwater:

The stormwater facilities proposed in “Village Park Preserve” are illustrated on the enclosed preliminary plans. Runoff from the site will be directed to storm sewer inlet locations, collected and conveyed to the proposed treatment pond(s) and filtration area(s). The ponds and filtration areas will provide temporary storage of stormwater runoff, treatment of stormwater and sediment removal. The stormwater plan will provide adequate treatment and storage to meet the City of Lake Elmo and the Valley Branch Watershed District requirements.

Traffic:

“Village Park Preserve” proposes one primary access point (Village Parkway) off of 30th Street North.

Traffic Generation – (anticipate 10 trips per day per home site)
104 Lots = 1,040 trips per day

Trail System:

Six-foot concrete sidewalks are proposed along residential streets within the site. In addition, there are 8.5 foot trails proposed to promote neighborhood connectivity.

Woodland Areas & Protection:

I. Introduction

A current tree survey in accordance with City of Lake Elmo requirements has been completed for this site and is included in the submittal. The tree inventory plan is shown on the Erosion Control Plan. 25 trees were identified, per the City requirements.

II. Tree Species, Distribution and Size:

The site has 467.5 caliper inches of significant trees, with 100.0 caliper inches of exempt trees for a net total of 367.5 caliper inches. The trees located throughout the site. The species include Cherry, Box Elder, Hackberry, Ash, and a few others. A table containing data on the trees, as well as a map which shows tree location, species, size and condition, are shown in the preliminary plans, please see the Erosion Control Plan.

Tree Removal & Restitution:

The “Village Park Preserve” development will impact approximately 22.6% of the significant trees on the site. The development is under the 30% threshold.

Landscape Plan, Monuments, & Entrance:

This development will have a parkway access from 30th Street North. Many of the lots will have pond views or overlook views, due to the site topography. The stormwater ponds and treatment areas will have landscaping to create unique water treatment facilities for the proposed project. A custom entry monument may be designed and constructed at the proposed entrance. This will create a sense of luxury and livability for the new single family residents, while providing safer access to the site. Landscaping, monuments and other furnishings will be designed to conform to the Lake Elmo Branding and Theming Study.

Homeowner’s Association and Restrictive Covenants:

The developer will prepare restrictive covenants and standards that will apply to this 104 lot project. The restrictive covenants will be tailored to the developer’s vision of the project. Each home will be required to meet the specifics of building types, landscaping, and overall goals of the development.

A master HOA will be created for the “Village Park Preserve” project. This association will be in charge of the monumentation, entrance, landscaping, and infiltration basins. The HOA will also be responsible for maintenance issues within the subdivision. These may include special landscaping, mailboxes, signage, and other common elements.

APPENDIX A:

Village Park Preserve– Preliminary Plat Lot Area Summary

BLOCK 1	GROSS AREA				WETLAND AREA		NET AREA			
Lot 1	22,997	s.f.	0.53	acres	0	s.f.	22,997	s.f.	0.53	acres
Lot 2	15,466	s.f.	0.36	acres	0	s.f.	15,466	s.f.	0.36	acres
Lot 3	16,238	s.f.	0.37	acres	0	s.f.	16,238	s.f.	0.37	acres
Lot 4	21,309	s.f.	0.49	acres	0	s.f.	21,309	s.f.	0.49	acres

Lot 5	15,634	s.f.	0.36	acres	0	s.f.	15,634	s.f.	0.36	acres
Lot 6	14,347	s.f.	0.33	acres	0	s.f.	14,347	s.f.	0.33	acres
Lot 7	12,999	s.f.	0.30	acres	0	s.f.	12,999	s.f.	0.30	acres
Lot 8	12,034	s.f.	0.28	acres	0	s.f.	12,034	s.f.	0.28	acres
Lot 9	11,518	s.f.	0.26	acres	0	s.f.	11,518	s.f.	0.26	acres
Lot 10	10,677	s.f.	0.25	acres	0	s.f.	10,677	s.f.	0.25	acres
Lot 11	13,329	s.f.	0.31	acres	0	s.f.	13,329	s.f.	0.31	acres
Lot 12	14,784	s.f.	0.34	acres	0	s.f.	14,784	s.f.	0.34	acres
Total	362,664	s.f.	8.33	acres	0	s.f.	362,664	s.f.	8.33	acres

BLOCK 2	GROSS AREA				WETLAND AREA		NET AREA			
Lot 1	18,200	s.f.	0.42	acres	0	s.f.	18,200	s.f.	0.42	acres
Lot 2	21,102	s.f.	0.48	acres	0	s.f.	21,102	s.f.	0.48	acres
Lot 3	16,406	s.f.	0.38	acres	0	s.f.	16,406	s.f.	0.38	acres
Lot 4	16,691	s.f.	0.38	acres	0	s.f.	16,691	s.f.	0.38	acres
Lot 5	18,012	s.f.	0.41	acres	0	s.f.	18,012	s.f.	0.41	acres
Lot 6	26,509	s.f.	0.61	acres	0	s.f.	26,509	s.f.	0.61	acres
Lot 7	27,055	s.f.	0.62	acres	0	s.f.	27,055	s.f.	0.62	acres
Lot 8	12,112	s.f.	0.28	acres	0	s.f.	12,112	s.f.	0.28	acres
Lot 9	12,164	s.f.	0.28	acres	0	s.f.	12,164	s.f.	0.28	acres
Lot 10	11,894	s.f.	0.27	acres	0	s.f.	11,894	s.f.	0.27	acres
Lot 11	10,988	s.f.	0.25	acres	0	s.f.	10,988	s.f.	0.25	acres
Lot 12	10,988	s.f.	0.25	acres	0	s.f.	10,988	s.f.	0.25	acres
Lot 13	10,988	s.f.	0.25	acres	0	s.f.	10,988	s.f.	0.25	acres
Lot 14	10,988	s.f.	0.25	acres	0	s.f.	10,988	s.f.	0.25	acres
Lot 15	13,012	s.f.	0.30	acres	0	s.f.	13,012	s.f.	0.30	acres
Total	474,218	s.f.	10.89	acres	0	s.f.	474,218	s.f.	10.89	acres

BLOCK 3	GROSS AREA				WETLAND AREA		NET AREA			
Lot 1	10,852	s.f.	0.25	acres	0	s.f.	10,852	s.f.	0.25	acres
Lot 2	8,813	s.f.	0.20	acres	0	s.f.	8,813	s.f.	0.20	acres
Lot 3	8,680	s.f.	0.20	acres	0	s.f.	8,680	s.f.	0.20	acres
Lot 4	8,342	s.f.	0.19	acres	0	s.f.	8,342	s.f.	0.19	acres

Lot 5	10,457	s.f.	0.24	acres	0	s.f.	10,457	s.f.	0.24	acres
Lot 6	10,407	s.f.	0.24	acres	0	s.f.	10,407	s.f.	0.24	acres
Lot 7	11,345	s.f.	0.26	acres	0	s.f.	11,345	s.f.	0.26	acres
Lot 8	13,467	s.f.	0.31	acres	0	s.f.	13,467	s.f.	0.31	acres
Lot 9	11,462	s.f.	0.26	acres	0	s.f.	11,462	s.f.	0.26	acres
Lot 10	10,266	s.f.	0.24	acres	0	s.f.	10,266	s.f.	0.24	acres
Lot 11	10,042	s.f.	0.23	acres	0	s.f.	10,042	s.f.	0.23	acres
Lot 12	8,862	s.f.	0.20	acres	0	s.f.	8,862	s.f.	0.20	acres
Lot 13	8,630	s.f.	0.20	acres	0	s.f.	8,630	s.f.	0.20	acres
Lot 14	8,450	s.f.	0.19	acres	0	s.f.	8,450	s.f.	0.19	acres
Lot 15	8,450	s.f.	0.19	acres	0	s.f.	8,450	s.f.	0.19	acres
Lot 16	8,450	s.f.	0.19	acres	0	s.f.	8,450	s.f.	0.19	acres
Total	313,950	s.f.	7.21	acres	0	s.f.	313,950	s.f.	7.21	acres

BLOCK 4	GROSS AREA				WETLAND AREA		NET AREA			
Lot 1	8,450	s.f.	0.19	acres	0	s.f.	8,450	s.f.	0.19	acres
Lot 2	8,827	s.f.	0.20	acres	0	s.f.	8,827	s.f.	0.20	acres
Lot 3	9,883	s.f.	0.23	acres	0	s.f.	9,883	s.f.	0.23	acres
Lot 4	11,251	s.f.	0.26	acres	0	s.f.	11,251	s.f.	0.26	acres
Lot 5	9,903	s.f.	0.23	acres	0	s.f.	9,903	s.f.	0.23	acres
Lot 6	10,166	s.f.	0.23	acres	0	s.f.	10,166	s.f.	0.23	acres
Lot 7	10,196	s.f.	0.23	acres	0	s.f.	10,196	s.f.	0.23	acres
Lot 8	9,903	s.f.	0.23	acres	0	s.f.	9,903	s.f.	0.23	acres
Lot 9	9,577	s.f.	0.22	acres	0	s.f.	9,577	s.f.	0.22	acres
Lot 10	8,915	s.f.	0.20	acres	0	s.f.	8,915	s.f.	0.20	acres
Lot 11	8,547	s.f.	0.20	acres	0	s.f.	8,547	s.f.	0.20	acres
Lot 12	8,999	s.f.	0.21	acres	0	s.f.	8,999	s.f.	0.21	acres
Lot 13	9,135	s.f.	0.21	acres	0	s.f.	9,135	s.f.	0.21	acres
Lot 14	9,135	s.f.	0.21	acres	0	s.f.	9,135	s.f.	0.21	acres
Lot 15	9,135	s.f.	0.21	acres	0	s.f.	9,135	s.f.	0.21	acres
Lot 16	9,135	s.f.	0.21	acres	0	s.f.	9,135	s.f.	0.21	acres
Total	302,314	s.f.	6.94	acres	0	s.f.	302,314	s.f.	6.94	acres

BLOCK	GROSS AREA				WETLAND		NET AREA			
--------------	-------------------	--	--	--	----------------	--	-----------------	--	--	--

5					AREA					
Lot 1	9,240	s.f.	0.21	acres	0	s.f.	9,240	s.f.	0.21	acres
Lot 2	9,108	s.f.	0.21	acres	0	s.f.	9,108	s.f.	0.21	acres
Lot 3	9,020	s.f.	0.21	acres	0	s.f.	9,020	s.f.	0.21	acres
Lot 4	9,020	s.f.	0.21	acres	0	s.f.	9,020	s.f.	0.21	acres
Lot 5	9,262	s.f.	0.21	acres	0	s.f.	9,262	s.f.	0.21	acres
Lot 6	9,262	s.f.	0.21	acres	0	s.f.	9,262	s.f.	0.21	acres
Lot 7	8,675	s.f.	0.20	acres	0	s.f.	8,675	s.f.	0.20	acres
Lot 8	11,717	s.f.	0.27	acres	0	s.f.	11,717	s.f.	0.27	acres
Total	150,608	s.f.	3.46	acres	0	s.f.	150,608	s.f.	3.46	acres

BLOCK 6	GROSS AREA				WETLAND AREA		NET AREA			
Lot 1	11,333	s.f.	0.26	acres	0	s.f.	11,333	s.f.	0.26	acres
Lot 2	8,509	s.f.	0.20	acres	0	s.f.	8,509	s.f.	0.20	acres
Lot 3	9,388	s.f.	0.22	acres	0	s.f.	9,388	s.f.	0.22	acres
Lot 4	10,729	s.f.	0.25	acres	0	s.f.	10,729	s.f.	0.25	acres
Lot 5	9,749	s.f.	0.22	acres	0	s.f.	9,749	s.f.	0.22	acres
Lot 6	11,229	s.f.	0.26	acres	0	s.f.	11,229	s.f.	0.26	acres
Total	121,874	s.f.	2.80	acres	0	s.f.	121,874	s.f.	2.80	acres

BLOCK 7	GROSS AREA				WETLAND AREA		NET AREA			
Lot 1	11,671	s.f.	0.27	acres	0	s.f.	11,671	s.f.	0.27	acres
Lot 2	9,380	s.f.	0.22	acres	0	s.f.	9,380	s.f.	0.22	acres
Lot 3	9,270	s.f.	0.21	acres	0	s.f.	9,270	s.f.	0.21	acres
Lot 4	9,925	s.f.	0.23	acres	0	s.f.	9,925	s.f.	0.23	acres
Lot 5	9,342	s.f.	0.21	acres	0	s.f.	9,342	s.f.	0.21	acres
Lot 6	10,430	s.f.	0.24	acres	0	s.f.	10,430	s.f.	0.24	acres
Lot 7	9,667	s.f.	0.22	acres	0	s.f.	9,667	s.f.	0.22	acres
Lot 8	10,140	s.f.	0.23	acres	0	s.f.	10,140	s.f.	0.23	acres
Lot 9	11,087	s.f.	0.25	acres	0	s.f.	11,087	s.f.	0.25	acres
Lot 10	11,343	s.f.	0.26	acres	0	s.f.	11,343	s.f.	0.26	acres
Lot 11	9,609	s.f.	0.22	acres	0	s.f.	9,609	s.f.	0.22	acres
Lot 12	8,579	s.f.	0.20	acres	0	s.f.	8,579	s.f.	0.20	acres
Lot 13	8,454	s.f.	0.19	acres	0	s.f.	8,454	s.f.	0.19	acres
Lot 14	10,400	s.f.	0.24	acres	0	s.f.	10,400	s.f.	0.24	acres
Total	278,594	s.f.	6.40	acres	0	s.f.	278,594	s.f.	6.40	acres

BLOCK 8	GROSS AREA				WETLAND AREA		NET AREA			
Lot 1	12,831	s.f.	0.29	acres	0	s.f.	12,831	s.f.	0.29	acres
Lot 2	11,279	s.f.	0.26	acres	0	s.f.	11,279	s.f.	0.26	acres
Lot 3	11,279	s.f.	0.26	acres	0	s.f.	11,279	s.f.	0.26	acres
Lot 4	11,189	s.f.	0.26	acres	0	s.f.	11,189	s.f.	0.26	acres
Lot 5	10,164	s.f.	0.23	acres	0	s.f.	10,164	s.f.	0.23	acres
Lot 6	9,736	s.f.	0.22	acres	0	s.f.	9,736	s.f.	0.22	acres
Lot 7	11,407	s.f.	0.26	acres	0	s.f.	11,407	s.f.	0.26	acres
Lot 8	11,408	s.f.	0.26	acres	0	s.f.	11,408	s.f.	0.26	acres
Lot 9	10,606	s.f.	0.24	acres	0	s.f.	10,606	s.f.	0.24	acres
Lot 10	10,632	s.f.	0.24	acres	0	s.f.	10,632	s.f.	0.24	acres
Lot 11	10,546	s.f.	0.24	acres	0	s.f.	10,546	s.f.	0.24	acres
Lot 12	9,965	s.f.	0.23	acres	0	s.f.	9,965	s.f.	0.23	acres
Lot 13	10,530	s.f.	0.24	acres	0	s.f.	10,530	s.f.	0.24	acres
Lot 14	10,530	s.f.	0.24	acres	0	s.f.	10,530	s.f.	0.24	acres
Lot 15	10,530	s.f.	0.24	acres	0	s.f.	10,530	s.f.	0.24	acres
Lot 16	10,530	s.f.	0.24	acres	0	s.f.	10,530	s.f.	0.24	acres
Lot 17	12,481	s.f.	0.29	acres	0	s.f.	12,481	s.f.	0.29	acres
Total	371,286	s.f.	8.52	acres	0	s.f.	371,286	s.f.	8.52	acres

OUTLOT	GROSS AREA				WETLAND AREA		NET AREA			
1	14,417	s.f.	0.33	acres	0	s.f.	14,417	s.f.	0.33	acres
2	686,961	s.f.	15.77	acres	0	s.f.	686,961	s.f.	15.77	acres
3	50,900	s.f.	1.17	acres	0	s.f.	50,900	s.f.	1.17	acres
4	32,677	s.f.	0.75	acres	0	s.f.	32,677	s.f.	0.75	acres
5	45,019	s.f.	1.03	acres	0	s.f.	45,019	s.f.	1.03	acres
6	262,419	s.f.	6.02	acres	0	s.f.	262,419	s.f.	6.02	acres
Total	2,184,786	s.f.	50.16	acres	0	s.f.	2,184,786	s.f.	50.16	acres

R/W	GROSS AREA				WETLAND AREA		NET AREA			
	473,313	s.f.	10.87	acres	0	s.f.	473,313	s.f.	10.87	acres


TOTAL	GROSS AREA				WETLAND AREA		NET AREA			
	4,730,142	s.f.	108.59	acres	0	s.f.	4,730,142	s.f.		acres



SHEET INDEX TABLE

SHEET	Description
SP	Site Plan
ALTA	ALTA/Existing Conditions
PP	Preliminary Plat
ST	Street Plan
UP	Utility Plan
GP	Grading Plan
EC	Erosion Control Plan
TS	Tree Survey
LP	Landscape Plan

PREPARED BY	PREPARED FOR
ENGINEER SATHRE-BERGQUIST, INC. 150 SOUTH BROADWAY WAYZATA, MINNESOTA 55391 PHONE: (952) 476-6000 FAX: (952) 476-0104 CONTACT: ROBERT S. MOLSTAD, P.E. EMAIL: MOLSTAD@SATHRE.COM	DEVELOPER GWSA DEVELOPMENT CHERYL CRAIG-ALLAN PHONE: (952) 546-5070 EMAIL: CRAIG@GWSACOMPANY.COM



EXISTING UTILITIES SHOWN ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISING OUT OF HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL EXISTING UTILITIES.

DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE PARCEL E	01	ERJ	08/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	08/14/14	STORM REVISIONS
CHECKED BY	03	ERJ	08/25/14	SHOW WETLAND B IMPACT
RSM				
DATE				
08/08/14				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Robert S. Molstad
 ROBERT S. MOLSTAD, P.E.
 Date: 08/08/14 Lic. No. 24728

ENGINEERS

SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN. 55391 (952) 476-6000

CITY PROJECT NO.
 LAKE ELMO, MINNESOTA

SITE PLAN
 VILLAGE PARK PRESERVE
 GWSA LAND DEVELOPMENT

FILE NO.
 3120-047
 SP
 SP

SURVEY LEGEND

- CATCH BASIN
- STORM MANHOLE
- SANITARY MANHOLE
- WATER MANHOLE
- HYDRANT
- GATE VALVE
- POWER POLE
- LIGHT PILE
- GUARDPOST
- GUY WIRE
- SIGN
- ELECTRIC TRANSFORMER
- TELEPHONE PEDestal
- ELECTRIC MANHOLE
- GAS VALVE
- TELEPHONE MANHOLE
- UTILITY MANHOLE
- ELECTRIC METER
- DENOTES 1/2 INCH X 1/4 INCH IRON MONUMENT SET MARKED T.S. 44565
- DENOTES IRON MONUMENT FOUND
- (-)- DENOTES RECORD MEASUREMENT
- STORM SEWER
- SANITARY SEWER
- WATER MAIN
- SANITARY SEWER SERVICE
- WATER SERVICE
- CULVERT
- UNDERGROUND ELECTRIC
- UNDERGROUND FIBER OPTIC
- UNDERGROUND GAS
- UNDERGROUND TELEPHONE
- OVERHEAD UTILITY
- CHAIN LINK FENCE
- CONCRETE CURB
- GAS METER

NORTH
 Readings Per Washington
 County Coordinate System
 (NAD 83-1983 A4)



SURVEY REPORT

The property depicted on this survey and the easements of record shown herein are the same as the property and the easements depicted in the Commission for Title Insurance issued by Custom Home Builders, LLC as issuing agent for Old Republic Title Insurance Company, File No. HB-20027A, dated August 6, 2013.

- 1) The following remarks reference items in Schedule B of Title Commitment No. HB-20027A (northerly property):
 - a) Item No. 1-9 are not survey related matters.
 - b) Item No. 10: A portion of the property contains wetlands which may be subject to federal, state, or local regulation. The right to use or improve this wetland is not surveyed herein. Please see item no. 13 of the Table A notes.
 - c) Item No. 11 Terms and conditions of Easement for gas purposes, in favor of Northern Natural Gas Company, as created in document dated December 3, 1955, filed February 2, 1956, as Document No. 154202. This document is marked in nature over all of the subject property. Claims Counsel may wish to pursue this matter so as to define the precise easement in an area that is actually being utilized for the 24" gas pipeline.
 - d) Item No. 12 Terms and conditions of Easement for highway purposes, in favor of County of Washington, as created in document dated September 20, 1993, filed May 21, 1993, as Document No. 229108. This easement lies westerly of the site and does not affect the subject property.

- 2) The following remarks reference items in Schedule B of Title Commitment No. HB-20066 (southerly property):
 - a) Item No. 6, 1-10 are not survey related matters.
 - b) Item No. 11 Terms and conditions of Easement for gas purposes, in favor of Northern Natural Gas Company, as created in document dated December 3, 1955, filed February 2, 1956, as Document No. 154202. Partially released by Partial release of easement, filed February 13, 1970, as Document No. 279001. Modified by Modification and Amendment of Easement Grant, filed December 6, 1978, as Document No. 304026. Modified by Modification and Amendment of Easement Grant, filed April 23, 1999, as Document No. 982264. Modified by Modification and Amendment of Easement Grant, filed February 11, 1997, as Document No. 921429. Modified by Agreement, filed September 22, 1997, as Document No. 946200.
 - c) **PLEASE NOTE:** The document No. 154202 is a gas easement that is blanket in nature over all of the South 33 acres of the South 1/2 of the Southwest Quarter. Document No. 279001 releases an area that lies 300 feet west of the subject property and does not affect the subject property. Document No. 304026 restricts the easement area to a 60 foot wide right of way that lies 300 feet west of the subject property. Doc. No. 982264 releases the pipeline easement slightly and changes the width to be 60 feet all of which does not affect the subject property. Doc. No. 921429 further defines the rights of the gas easement for that portion which lies 300 feet west of the site, it does not affect the subject property. Document No. 946200 is an unrecorded agreement to relinquish rights that is westerly of 30th Street North, and does not affect the subject property.
 - d) Item No. 12 Terms and conditions of Easement for highway purposes, in favor of County of Washington, as created in document dated September 18, 1993, filed May 21, 1993, as Document No. 229110. This easement lies westerly of the westerly line of CSAH No. 15 and does not affect the subject property.
 - e) Item No. 13 Subject to 30th Street N, as laid out and traversed over the southerly 30 feet more or less. Please note that we have shown the right-of-way of 30th Street North across the southerly part of the site. We have surveyed it as a right-of-way that extends 33 feet north from the center line of the relatively paved road. This is per the historic practice of providing 66 feet of right-of-way on roads that develop via prescriptive rights. Based upon contemporary case law this right-of-way could be construed to be of more or less width based upon a determination of what area is actually being utilized for highway purposes including drainage and possibly slopes.
 - f) Item No. 14 Subject to CSAH No. 15, Manning Avenue N, as laid out and traversed over the easterly 50 feet more or less. This item is correlated with the area needed to Washington County per quit claim deed that as document no. 158377, and does not affect the subject property.

- 3) Corridors such as (but not limited to) easements, pipelines, access, drainage, and easements and/or servitudes.
 - a) Along the easterly boundary line there is a driving lead located between the subject properties, laid and the adjacent to the north. We are not aware of who is using this lead.
 - b) Along the westerly side of the site there are walking trails in the wooded area. We are not aware of who is using these trails.
 - c) Please note there is an overlap of approximately 4 feet between the south line of the subject property and the north line of the adjoining southerly properties. Claims Counsel may wish to pursue this matter so as to determine the junior/senior rights of this site.

CERTIFICATION

To: Zehlen Farms Inc, a corporation under the laws of Minnesota, and Custom Home Builders Title, LLC as Issuing Agent for Old Republic National Title Insurance Company.

This is to certify that this map or plan and the survey on which it is based were made in accordance with the 2015 Minnesota Standard Detail Requirements for ALTA/ACSM Land Title Surveys, properly established and adopted by ALTA and NSPS in 2011, and includes items 1, 4, 7a, 8, 9 and 11(a) of Table A thereof. The field work was completed on September 31, 2012.

Date of Field Map: October 16, 2012

Hory L. Gynselski, T.L.S.
 hory.gynselski@sathre.com
 Minnesota License No. 44595

DESCRIPTION OF PROPERTY SURVEYED

Par Schedule A of Title Commitment No. HB-20027A (northerly property)

The North 50 acres of the South Half of the Southwest Quarter of Section 13, Township 29 North, Range 21 West, Washington County, Minnesota, except that part which lies westerly of the following described line:

Commencing at the southeast corner of said Southwest Quarter, thence South 85 degrees 45 minutes 30 seconds West along the South line of said Southwest Quarter, 159.73 feet (readings are based on the Washington County Coordinate System); thence North 01 degree 14 minutes 20 seconds West, 33 feet; thence North 45 degrees 50 minutes 50 seconds East, 142.10 feet to the point of beginning of the line to be described; thence North 00 degrees 45 minutes 51 seconds West, 1188.18 feet to said North line of said South Half of the Southwest Quarter and said line thence terminating.

Abstract Property:

Par Schedule A of Title Commitment No. HB-20066 (southerly property)

The South 499.6 feet of the South Half of the Southwest Quarter (S 1/2 of SE 1/4) Section Thirteen (13) Township Twenty Nine North (29N), Range Twenty one West (21W), except the West 1273.0 feet of the Southwest Quarter of said Section Thirteen (13) and excepting therefrom that portion of the above tract conveyed to the County of Washington by that county's Quit Claim Deed Head March 30, 1997, and Rec of record in the Office of the Washington County Recorder on April 2, 1997 as Document No. 925137.

Abstract Property:

- ALTA/ACSM OPTIONAL TABLE A NOTES**
- (The following items refer to Table A optional survey responsibilities and specifications.)
2. Unsurveyed Areas: Lake Elmo, Minnesota (PID: 03 029 21 43 0004 (98-26227A) and No. 13 029 21 43 0002 (98-2080)).
 3. This property is contained in Zone X (area of minimal flooding) per Flood Insurance Rate Map: Community Panel No. 27163C0035E effective date of February 3, 2010.
 4. The Gross land area is 2,798.244 +/- Sq. Ft. or 03 05 +/- Acres. Wetland is 17,468 +/- Sq. Ft. or 0.40 +/- Acres. BOW = 39,804 +/- Sq. Ft. or 0.91 +/- Acres. NAT = 27,409,524 +/- Sq. Ft. or 62.54 +/- Acres.
 5. Elevations are based on a MNDOT Geomatics Marker (C349) located on the west side of Manning Ave North approximately 2000 feet north of the subject property, 17 feet northwest of a metal shed and 4 feet east of a power pole having an elevation of 924.22 feet NAVD 1988. The contours were obtained from LIDAR mapping data was downloaded from the Minnesota Department of Natural Resources on September 20, 2012.
 6. The zoning for the subject property is RT (Rural Transitional) per the City of Lake Elmo's zoning map dated May 2013. The planning department informed us per a phone call that the property is in the process of changing to Village Low Density. Per this phone call, the setback, height, and density restrictions for this zoning designation are going to be as follows: SETBACKS - Front 25 feet, Side 10 feet, and 5 feet garage. Rear 20 feet. DENSITY - 1.5 - 2.0 and per acre.
 7. We have shown the location of utilities on the surveyed property by covered excavation only. Please Contact GOPHER STATE ONE CALL at 855-454-0002 for the location of underground utilities prior to any excavation.
 8. The Wetland delineation was performed by Klamath Environmental Service and the delineation page was loaded on October 1, 2013.

FIELD CREW	NO.	BY	DATE	REVISIONS
RLS		RLS	12-11-13	Added Wetland Areas to the Graphics
DRAWN BY		RLS		
CHECKED BY		DSP		
DATE				
			10-17-13	

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INCUR THE LIABILITY OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.



SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY, WAYZATA, MN 55391 (952) 476-6000

ENGINEERED SURVEYING
 LAND SURVEYING PLANNING


TWP 29 - RGE 21 - SEC 13
 WASHINGTON COUNTY
 BOUNDARY SURVEY.DWG

LAKE ELMO, MINNESOTA

ALTA/ACSM LAND TITLE SURVEY
 PREPARED FOR:
GW LAND DEVELOPMENT
CUSTOM HOME BUILDERS TITLE, LLC
OLD REPUBLIC NATIONAL TITLE INSURANCE COMPANY

FILE NO. 3120-047 PARCEL E

1



VILLAGE PARK PRESERVE LAKE ELMO, MINNESOTA

DESCRIPTION OF PROPERTY SURVEYED
(Per Schedule A of the herein referenced Title Commitment)

Per Schedule A of Title Commitment No. HB-26627A (northerly property)

The North 50 acres of the South Half of the Southeast Quarter of Section 13, Township 29 North, Range 21 West, Washington County, Minnesota, except that part which lies easterly of the following described line:

Commencing at the southeast corner of said Southeast Quarter; thence South 88 degrees 45 minutes 30 seconds West along the South line of said Southeast Quarter, 159.73 feet (bearings are based on the Washington County Coordinate System); thence North 01 degree 14 minutes 30 seconds West, 33 feet; thence North 43 degrees 59 minutes 50 seconds East, 142.10 feet to the point of beginning of the line to be described; thence North 00 degrees 45 minutes 51 seconds West, 1188.14 feet to said North line of said South Half of the Southeast Quarter and said line there terminating.

Abstract Property.

Per Schedule A of Title Commitment No. HB-26880 (southerly property)

The South 498.6 feet of the South Half of the Southeast Quarter (S1/2 of SE1/4); Section Thirteen (13), Township Twenty Nine North (29N.), Range Twenty-one West (21W.), except the West 1273.0 feet of the South Half of the Southeast Quarter of said Section Thirteen (13). And excepting therefrom that portion of the above tract conveyed to the County of Washington by that certain Quit Claim Deed dated March 30, 1987, and filed of record in the Office of the Washington County Recorder on April 2, 1987 as Document No. 535377.

Abstract Property.

BRAGHAUD AND UTILITY EASEMENTS ARE SHOWN HERE.



Being 1 foot in width and adjoining the lines, unless otherwise indicated, and 10 feet in width and adjoining right of way lines, unless otherwise indicated, as shown on the plan.



PREPARED BY		PREPARED FOR	
SATHRE-BERGQUIST, INC. 150 SOUTH BROADWAY WAYZATA, MINNESOTA 55391 PHONE: (952) 478-0000 FAX: (952) 478-0104 CONTACT: RORY L. SYRSTEDT EMAIL: rory@satb.com		SATHRE-BERGQUIST, INC. 150 SOUTH BROADWAY WAYZATA, MINNESOTA 55391 PHONE: (952) 478-0000 FAX: (952) 478-0104 CONTACT: RORY L. SYRSTEDT EMAIL: rory@satb.com	
104 SINGLE FAMILY LOTS			
LOT NO.	AREA	FRONT	REAR
104	0.25 AC	110 FT	110 FT




GENERAL NOTES

- Site Address: Unassigned, Lake Elmo, MN 55042; PID NO. 13.029.21.43.0004 (HB-26627A) and No. 13.029.21.44.0002 (HB-26880).
- Flood Zone: Parcels are contained in Zone X (area of minimal flooding) per Flood Insurance Rate Map, Community Panel No. 27163C0355E, effective date of February 3, 2010.
- Parcel Area: Gross- 2,768,244 Sq. Ft. - 63.55 Acres
Wetland- 17,488 Sq. Ft. - 0.40 Acres
ROW- 39,804 Sq. Ft. - 0.91 Acres
Net- 2,710,952 Sq. Ft. - 62.24 Acres
- Benchmark: Elevations are based on MNDOT Geodetic Marker (CJ49) located on the west side of Manning Ave North approximately 2300 feet north of the subject property, 17 feet northwest of a metal shed and 4 feet east of a power pole having an elevation of 824.32 feet NAVD 1988. The contours were obtained from LIDAR mapping that was downloaded from the Minnesota Department of Natural Resources on September 20, 2013.
- Zoning: The current Zoning for the subject property is RT (Rural Transitional) per the City of Lake Elmo's zoning map dated May 2013. The planning department informed us per a phone call that the property is in the process of changing to Village Low Density. Per this phone call, the setback, height, and density restrictions for this zoning designation are going to be as follows: SETBACKS - Front 25 feet, Side 10 feet living and 5 feet garage, Rear 20 feet; HEIGHT - 35 feet; DENSITY - 1.5 - 2 unit per acre.
- Location of Utilities: We have shown the location of utilities on the surveyed property by observed evidence only.
- Wetland: Kjothaug Environmental Services were at the property on October 1, 2013.

350' BUFFER IDENTIFYING LAND OWNERS AND BOUNDARY LINES FOR ADJOINING PARCELS.
(SHOWN PER COUNTY GIS MAPPING)



SURVEY LEGEND	
IRON PIPE SET	GRAVEL - EXISTING
IRON PIPE FOUND	BITUMINOUS - EXISTING
DRY WIRE - EXISTING	EASEMENT - EXISTING
POWER POLE - EXISTING	BOUNDARY LINE - EXISTING
TELEPHONE PEDESTAL - EXISTING	ADJACENT PROPERTY LINE - EXISTING
OVERHEAD UTILITY - EXISTING	SECTION LINE - EXISTING
WOODS - EXISTING	CENTERLINE - PROPOSED
EASEMENT LINE - PROPOSED	RIGHT OF WAY - PROPOSED
SETBACK LINE - PROPOSED	LOT LINE - PROPOSED
LOT WIDTH LINE - PROPOSED	CURVE RADIAL LINE - PROPOSED
REAR BUILDING PAD LINE - PROPOSED	CONCRETE CURB AND GUTTER - PROPOSED
	BITUMINOUS SURFACE - EXISTING
	BITUMINOUS SURFACE - PROPOSED
	WETLAND - EXISTING
	GRAVEL - EXISTING
	CONCRETE SIDEWALK - PROPOSED
	POND - PROPOSED
	INFILTRATION - PROPOSED
	BLOCK LINE - PROPOSED



THE NORTH 50 ACRES OF

THE SOUTH HALF OF THE COURTS QUARTER OF

24" Gas Pipeline as shown in Doc. No. 3979697

Stormwater Pond #4SE
Nw - 912.5
Hw - 916.0
56,896 SQ. FT.


31ST STREET NORTH

N89°32'18"E 1273.04

FIELD CREW	NO.	BY	DATE	REVISIONS
RLS				
DRAWN BY				
JML				
CHECKED BY				
RLS				
DATE				
08-04-14				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I hereby certify that this survey, plan or report was prepared by me or under my direct supervision and that I am a duly Licensed Land Surveyor under the laws of the State of Minnesota.
Dated this 7th day of August, 2014.
Roy L. Symonien, PLS
roy@satbre.com
Minnesota License No. 44565



SATHRE-BERGQUIST, INC.
150 SOUTH BROADWAY WAYZATA, MN. 55391 (952) 476-6000

TWP 29 - RGE 21 - SEC. 13
WASHINGTON COUNTY
PrePlat Parcel E.DWG
**LAKE ELMO,
MINNESOTA**

**PRELIMINARY PLAT
OF
VILLAGE PARK PRESERVE**

FILE NO.
3120-047
PP-3
PP-6



FIELD CREW	NO.	BY	DATE	REVISIONS
RLS				
DRAWN BY				
JML				
CHECKED BY				
RLS				
DATE				
08-04-14				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.


I hereby certify that this survey, plan or report was prepared by me or under my direct supervision and that I am a duly Licensed Land Surveyor under the laws of the State of Minnesota.
 Dated this 7th day of August, 2014.
 Rory L. Synnott, PLS
 rory@sathre.com
 Minnesota License No. 44564

SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN, 55391 (952) 476-6000

TWP.29 - RGE.21 - SEC.13
 WASHINGTON COUNTY
 Pre-Plat Parcel E.DWG
**LAKE ELMO,
 MINNESOTA**

**PRELIMINARY PLAT
 OF
 VILLAGE PARK PRESERVE**

FILE NO.
 3120-047
PP-4
PP-6



FIELD CREW	NO.	BY	DATE	REVISIONS
RLS				
DRAWN BY				
JML				
CHECKED BY				
RLS				
DATE				
08-04-14				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I hereby certify that this survey, plan or report was prepared by me or under my direct supervision and that I am a duly Licensed Land Surveyor under the laws of the State of Minnesota.
 Dated this 7th day of August, 2014.
 Roy L. Synaloff, PLS
 Minnesota License No. 44565
 roy@saifree.com

SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN, 55391 (952) 478-6000

TWP.29 - RGE.21 - SEC.13
 WASHINGTON COUNTY
 PrePlat Parcel E.DWG
LAKE ELMO, MINNESOTA

PRELIMINARY PLAT
 OF
VILLAGE PARK PRESERVE

FILE NO.
 3120-047
PP-5
 PP-6

LOT TAB SHEET

BLOCK 1	GROSS AREA	WETLAND AREA	NET AREA	WIDTH @ SETBACK
Lot 1	22,997 s.f. 0.33 acres	0 s.f.	22,997 s.f. 0.33 acres	56.9' w/ 1E
Lot 2	15,466 s.f. 0.36 acres	0 s.f.	15,466 s.f. 0.36 acres	74.4' w/ 1E
Lot 3	16,236 s.f. 0.37 acres	0 s.f.	16,236 s.f. 0.37 acres	74.8' w/ 1E
Lot 4	17,898 s.f. 0.41 acres	0 s.f.	17,898 s.f. 0.41 acres	86.6' w/ 1E
Lot 5	15,634 s.f. 0.36 acres	0 s.f.	15,634 s.f. 0.36 acres	100.1' w/ 1E
Lot 6	14,347 s.f. 0.33 acres	0 s.f.	14,347 s.f. 0.33 acres	95.1' w/ 1E
Lot 7	12,999 s.f. 0.30 acres	0 s.f.	12,999 s.f. 0.30 acres	82.1' w/ 1E
Lot 8	12,034 s.f. 0.28 acres	0 s.f.	12,034 s.f. 0.28 acres	80.9' w/ 1E
Lot 9	11,518 s.f. 0.26 acres	0 s.f.	11,518 s.f. 0.26 acres	83.8' w/ 1E
Lot 10	10,677 s.f. 0.25 acres	0 s.f.	10,677 s.f. 0.25 acres	81' w/ 1E
Lot 11	13,329 s.f. 0.31 acres	0 s.f.	13,329 s.f. 0.31 acres	81' w/ 1E
Lot 12	14,784 s.f. 0.34 acres	0 s.f.	14,784 s.f. 0.34 acres	81' w/ 1E
Total	202,664 s.f. 8.33 acres	0 s.f.	202,664 s.f. 8.33 acres	

BLOCK 2	GROSS AREA	WETLAND AREA	NET AREA	WIDTH @ SETBACK
Lot 1	18,200 s.f. 0.42 acres	0 s.f.	18,200 s.f. 0.42 acres	81.5' w/ 1E
Lot 2	21,102 s.f. 0.48 acres	0 s.f.	21,102 s.f. 0.48 acres	82.1' w/ 1E
Lot 3	16,406 s.f. 0.38 acres	0 s.f.	16,406 s.f. 0.38 acres	81' w/ 1E
Lot 4	16,991 s.f. 0.39 acres	0 s.f.	16,991 s.f. 0.39 acres	81' w/ 1E
Lot 5	15,012 s.f. 0.41 acres	0 s.f.	15,012 s.f. 0.41 acres	81' w/ 1E
Lot 6	26,509 s.f. 0.61 acres	0 s.f.	26,509 s.f. 0.61 acres	81' w/ 1E
Lot 7	27,055 s.f. 0.62 acres	0 s.f.	27,055 s.f. 0.62 acres	80.2' w/ 1E
Lot 8	12,112 s.f. 0.28 acres	0 s.f.	12,112 s.f. 0.28 acres	80.7' w/ 1E
Lot 9	12,164 s.f. 0.28 acres	0 s.f.	12,164 s.f. 0.28 acres	81' w/ 1E
Lot 10	11,894 s.f. 0.27 acres	0 s.f.	11,894 s.f. 0.27 acres	81.2' w/ 1E
Lot 11	10,988 s.f. 0.25 acres	0 s.f.	10,988 s.f. 0.25 acres	81' w/ 1E
Lot 12	10,988 s.f. 0.25 acres	0 s.f.	10,988 s.f. 0.25 acres	81' w/ 1E
Lot 13	10,988 s.f. 0.25 acres	0 s.f.	10,988 s.f. 0.25 acres	81' w/ 1E
Lot 14	10,988 s.f. 0.25 acres	0 s.f.	10,988 s.f. 0.25 acres	81' w/ 1E
Lot 15	13,012 s.f. 0.30 acres	0 s.f.	13,012 s.f. 0.30 acres	90' w/ 1E
Total	474,218 s.f. 10.89 acres	0 s.f.	474,218 s.f. 10.89 acres	

BLOCK 3	GROSS AREA	WETLAND AREA	NET AREA	WIDTH @ SETBACK
Lot 1	10,352 s.f. 0.24 acres	0 s.f.	10,352 s.f. 0.24 acres	80' w/ 1E
Lot 2	8,313 s.f. 0.20 acres	0 s.f.	8,313 s.f. 0.20 acres	65' w/ 1E
Lot 3	8,680 s.f. 0.20 acres	0 s.f.	8,680 s.f. 0.20 acres	65' w/ 1E
Lot 4	8,342 s.f. 0.19 acres	0 s.f.	8,342 s.f. 0.19 acres	65' w/ 1E
Lot 5	10,457 s.f. 0.24 acres	0 s.f.	10,457 s.f. 0.24 acres	66.9' w/ 1E
Lot 6	10,407 s.f. 0.24 acres	0 s.f.	10,407 s.f. 0.24 acres	72.9' w/ 1E
Lot 7	11,345 s.f. 0.26 acres	0 s.f.	11,345 s.f. 0.26 acres	77.8' w/ 1E
Lot 8	13,467 s.f. 0.31 acres	0 s.f.	13,467 s.f. 0.31 acres	88.9' w/ 1E
Lot 9	11,467 s.f. 0.26 acres	0 s.f.	11,467 s.f. 0.26 acres	71' w/ 1E
Lot 10	10,266 s.f. 0.24 acres	0 s.f.	10,266 s.f. 0.24 acres	72.9' w/ 1E
Lot 11	10,042 s.f. 0.23 acres	0 s.f.	10,042 s.f. 0.23 acres	69.5' w/ 1E
Lot 12	8,862 s.f. 0.20 acres	0 s.f.	8,862 s.f. 0.20 acres	66' w/ 1E
Lot 13	8,630 s.f. 0.20 acres	0 s.f.	8,630 s.f. 0.20 acres	65.1' w/ 1E
Lot 14	8,490 s.f. 0.19 acres	0 s.f.	8,490 s.f. 0.19 acres	65' w/ 1E
Lot 15	8,490 s.f. 0.19 acres	0 s.f.	8,490 s.f. 0.19 acres	65' w/ 1E
Lot 16	8,490 s.f. 0.19 acres	0 s.f.	8,490 s.f. 0.19 acres	65' w/ 1E
Total	113,980 s.f. 2.61 acres	0 s.f.	113,980 s.f. 2.61 acres	

BLOCK 4	GROSS AREA	WETLAND AREA	NET AREA	WIDTH @ SETBACK
Lot 1	8,450 s.f. 0.19 acres	0 s.f.	8,450 s.f. 0.19 acres	53' w/ 1E
Lot 2	8,827 s.f. 0.20 acres	0 s.f.	8,827 s.f. 0.20 acres	72.7' w/ 1E
Lot 3	9,883 s.f. 0.23 acres	0 s.f.	9,883 s.f. 0.23 acres	77' w/ 1E
Lot 4	11,251 s.f. 0.26 acres	0 s.f.	11,251 s.f. 0.26 acres	74.8' w/ 1E
Lot 5	9,903 s.f. 0.23 acres	0 s.f.	9,903 s.f. 0.23 acres	64.9' w/ 1E
Lot 6	10,166 s.f. 0.23 acres	0 s.f.	10,166 s.f. 0.23 acres	64.9' w/ 1E
Lot 7	10,196 s.f. 0.23 acres	0 s.f.	10,196 s.f. 0.23 acres	64.9' w/ 1E
Lot 8	9,903 s.f. 0.23 acres	0 s.f.	9,903 s.f. 0.23 acres	64.9' w/ 1E
Lot 9	9,571 s.f. 0.22 acres	0 s.f.	9,571 s.f. 0.22 acres	78.1' w/ 1E
Lot 10	8,915 s.f. 0.20 acres	0 s.f.	8,915 s.f. 0.20 acres	77' w/ 1E
Lot 11	8,547 s.f. 0.20 acres	0 s.f.	8,547 s.f. 0.20 acres	67.2' w/ 1E
Lot 12	8,999 s.f. 0.21 acres	0 s.f.	8,999 s.f. 0.21 acres	68.2' w/ 1E
Lot 13	9,155 s.f. 0.21 acres	0 s.f.	9,155 s.f. 0.21 acres	68.4' w/ 1E
Lot 14	9,155 s.f. 0.21 acres	0 s.f.	9,155 s.f. 0.21 acres	68.4' w/ 1E
Lot 15	9,155 s.f. 0.21 acres	0 s.f.	9,155 s.f. 0.21 acres	68.4' w/ 1E
Lot 16	9,155 s.f. 0.21 acres	0 s.f.	9,155 s.f. 0.21 acres	68.4' w/ 1E
Total	202,314 s.f. 6.94 acres	0 s.f.	202,314 s.f. 6.94 acres	

BLOCK 5	GROSS AREA	WETLAND AREA	NET AREA	WIDTH @ SETBACK
Lot 1	9,240 s.f. 0.21 acres	0 s.f.	9,240 s.f. 0.21 acres	78.7' w/ 1E
Lot 2	9,108 s.f. 0.21 acres	0 s.f.	9,108 s.f. 0.21 acres	78.7' w/ 1E
Lot 3	9,020 s.f. 0.21 acres	0 s.f.	9,020 s.f. 0.21 acres	76.7' w/ 1E
Lot 4	9,020 s.f. 0.21 acres	0 s.f.	9,020 s.f. 0.21 acres	65' w/ 1E
Lot 5	9,262 s.f. 0.21 acres	0 s.f.	9,262 s.f. 0.21 acres	64.0' w/ 1E
Lot 6	9,262 s.f. 0.21 acres	0 s.f.	9,262 s.f. 0.21 acres	64.9' w/ 1E
Lot 7	8,625 s.f. 0.20 acres	0 s.f.	8,625 s.f. 0.20 acres	65' w/ 1E
Lot 8	11,717 s.f. 0.27 acres	0 s.f.	11,717 s.f. 0.27 acres	77.1' w/ 1E
Total	130,608 s.f. 3.46 acres	0 s.f.	130,608 s.f. 3.46 acres	

BLOCK 6	GROSS AREA	WETLAND AREA	NET AREA	WIDTH @ SETBACK
Lot 1	11,339 s.f. 0.26 acres	0 s.f.	11,339 s.f. 0.26 acres	86.7' w/ 1E
Lot 2	8,509 s.f. 0.20 acres	0 s.f.	8,509 s.f. 0.20 acres	66.4' w/ 1E
Lot 3	9,388 s.f. 0.22 acres	0 s.f.	9,388 s.f. 0.22 acres	65' w/ 1E
Lot 4	10,729 s.f. 0.25 acres	0 s.f.	10,729 s.f. 0.25 acres	74.4' w/ 1E
Lot 5	9,749 s.f. 0.22 acres	0 s.f.	9,749 s.f. 0.22 acres	75' w/ 1E
Lot 6	11,229 s.f. 0.26 acres	0 s.f.	11,229 s.f. 0.26 acres	85' w/ 1E
Total	121,871 s.f. 2.80 acres	0 s.f.	121,871 s.f. 2.80 acres	

BLOCK 7	GROSS AREA	WETLAND AREA	NET AREA	WIDTH @ SETBACK
Lot 1	11,871 s.f. 0.27 acres	0 s.f.	11,871 s.f. 0.27 acres	89.1' w/ 1E
Lot 2	9,389 s.f. 0.22 acres	0 s.f.	9,389 s.f. 0.22 acres	64.9' w/ 1E
Lot 3	9,270 s.f. 0.21 acres	0 s.f.	9,270 s.f. 0.21 acres	74.1' w/ 1E
Lot 4	9,925 s.f. 0.23 acres	0 s.f.	9,925 s.f. 0.23 acres	64.9' w/ 1E
Lot 5	9,342 s.f. 0.21 acres	0 s.f.	9,342 s.f. 0.21 acres	74.9' w/ 1E
Lot 6	10,430 s.f. 0.24 acres	0 s.f.	10,430 s.f. 0.24 acres	80' w/ 1E
Lot 7	9,667 s.f. 0.22 acres	0 s.f.	9,667 s.f. 0.22 acres	70' w/ 1E
Lot 8	10,140 s.f. 0.23 acres	0 s.f.	10,140 s.f. 0.23 acres	66.9' w/ 1E
Lot 9	11,087 s.f. 0.25 acres	0 s.f.	11,087 s.f. 0.25 acres	100.8' w/ 1E
Lot 10	11,343 s.f. 0.26 acres	0 s.f.	11,343 s.f. 0.26 acres	97.7' w/ 1E
Lot 11	9,600 s.f. 0.22 acres	0 s.f.	9,600 s.f. 0.22 acres	80.7' w/ 1E
Lot 12	8,579 s.f. 0.20 acres	0 s.f.	8,579 s.f. 0.20 acres	65' w/ 1E
Lot 13	8,454 s.f. 0.19 acres	0 s.f.	8,454 s.f. 0.19 acres	65' w/ 1E
Lot 14	10,400 s.f. 0.24 acres	0 s.f.	10,400 s.f. 0.24 acres	80' w/ 1E
Total	274,594 s.f. 6.40 acres	0 s.f.	274,594 s.f. 6.40 acres	

BLOCK 8	GROSS AREA	WETLAND AREA	NET AREA	WIDTH @ SETBACK
Lot 1	12,831 s.f. 0.29 acres	0 s.f.	12,831 s.f. 0.29 acres	96' w/ 1E
Lot 2	11,279 s.f. 0.26 acres	0 s.f.	11,279 s.f. 0.26 acres	81' w/ 1E
Lot 3	11,279 s.f. 0.26 acres	0 s.f.	11,279 s.f. 0.26 acres	81' w/ 1E
Lot 4	11,189 s.f. 0.26 acres	0 s.f.	11,189 s.f. 0.26 acres	81' w/ 1E
Lot 5	10,164 s.f. 0.23 acres	0 s.f.	10,164 s.f. 0.23 acres	91.8' w/ 1E
Lot 6	9,736 s.f. 0.22 acres	0 s.f.	9,736 s.f. 0.22 acres	84.3' w/ 1E
Lot 7	11,407 s.f. 0.26 acres	0 s.f.	11,407 s.f. 0.26 acres	106.1' w/ 1E
Lot 8	11,408 s.f. 0.26 acres	0 s.f.	11,408 s.f. 0.26 acres	101.4' w/ 1E
Lot 9	10,606 s.f. 0.24 acres	0 s.f.	10,606 s.f. 0.24 acres	83.8' w/ 1E
Lot 10	10,632 s.f. 0.24 acres	0 s.f.	10,632 s.f. 0.24 acres	99.4' w/ 1E
Lot 11	10,546 s.f. 0.24 acres	0 s.f.	10,546 s.f. 0.24 acres	98.7' w/ 1E
Lot 12	9,965 s.f. 0.23 acres	0 s.f.	9,965 s.f. 0.23 acres	85.3' w/ 1E
Lot 13	10,530 s.f. 0.24 acres	0 s.f.	10,530 s.f. 0.24 acres	81' w/ 1E
Lot 14	10,530 s.f. 0.24 acres	0 s.f.	10,530 s.f. 0.24 acres	81' w/ 1E
Lot 15	10,530 s.f. 0.24 acres	0 s.f.	10,530 s.f. 0.24 acres	81' w/ 1E
Lot 16	10,530 s.f. 0.24 acres	0 s.f.	10,530 s.f. 0.24 acres	81' w/ 1E
Lot 17	12,481 s.f. 0.29 acres	0 s.f.	12,481 s.f. 0.29 acres	96' w/ 1E
Total	171,286 s.f. 8.52 acres	0 s.f.	171,286 s.f. 8.52 acres	

OUTLOT	GROSS AREA	WETLAND AREA	NET AREA	WIDTH @ SETBACK
1	14,417 s.f. 0.33 acres	0 s.f.	14,417 s.f. 0.33 acres	0' w/ 1E
2	68,961 s.f. 1.57 acres	0 s.f.	68,961 s.f. 1.57 acres	0' w/ 1E
3	50,900 s.f. 1.17 acres	0 s.f.	50,900 s.f. 1.17 acres	0' w/ 1E
4	32,677 s.f. 0.75 acres	0 s.f.	32,677 s.f. 0.75 acres	0' w/ 1E
5	45,019 s.f. 1.03 acres	0 s.f.	45,019 s.f. 1.03 acres	0' w/ 1E
6	262,419 s.f. 6.07 acres	0 s.f.	262,419 s.f. 6.07 acres	0' w/ 1E
Total	2,184,785 s.f. 50.16 acres	0 s.f.	2,184,785 s.f. 50.16 acres	

R/W	GROSS AREA	WETLAND AREA	NET AREA	WIDTH @ SETBACK
473,313 s.f. 10.87 acres	0 s.f.	473,313 s.f. 10.87 acres	0' w/ 1E	
TOTAL	4,730,142 s.f. 108.59 acres	0 s.f.	4,730,142 s.f. 108.59 acres	

FIELD CREW	NO.	BY	DATE	REVISIONS
RLS				
DRAWN BY				
JML				
CHECKED BY				
RLS				
DATE				
08-04-14				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I hereby certify that this survey, plan or report was prepared by me or under my direct supervision and that I am a duly Licensed Land Surveyor under the laws of the State of Minnesota.
 Dated this 7th day of August, 2014.

 Rory L. Symmetten, PLS
 Minnesota License No. 44564
 rory@sathre.com



SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN. 55381 (952) 478-0000

TWP 29 - RGE 21 - SEC. 13
 WASHINGTON COUNTY
 Plat Parcel E.DWG
**LAKE ELMO,
 MINNESOTA**

**PRELIMINARY PLAT
 OF
 VILLAGE PARK PRESERVE**

FILE NO.
 3129-047
PP-6
PP-6



RD1

Number	Station	Radius	Length	Line/Chord Direction	Delta Angle
L1	0+00.00		151.01	N0° 25' 34.56"W	
C1	1+51.81	250.00	175.38	N19° 40' 15.37"E	40°11'40"
L2	3+26.99		84.53	N29° 48' 05.30"E	
C2	4+21.52	750.00	527.92	N19° 36' 11.85"E	40°19'47"
L3	9+49.44		449.62	N0° 33' 42.00"W	

RD2

Number	Station	Radius	Length	Line/Chord Direction	Delta Angle
C3	0+00.00	375.00	377.92	S84° 12' 41.54"E	87°44'33"
C4	3+77.92	300.00	209.78	N86° 56' 52.45"E	40°03'41"
C5	5+87.68	125.00	255.28	N48° 28' 21.43"E	117°00'43"
C6	8+42.96	500.00	133.66	N2° 22' 30.70"W	15°18'59"
L4	9+76.62		354.84	N5° 18' 58.57"E	
C7	13+31.48	225.00	402.59	N45° 58' 37.10"W	102°31'11"
C8	17+34.08	1000.00	119.24	S88° 00' 01.70"W	6°46'29"
L5	18+52.30		156.22	S89° 32' 16.19"W	

RD3

Number	Station	Radius	Length	Line/Chord Direction	Delta Angle
L6	0+00.00		31.51	N83° 13' 33.26"W	
C9	0+31.51	400.00	304.07	S74° 58' 49.24"W	43°33'15"
C10	3+35.58	275.00	170.10	S70° 56' 22.97"W	35°26'22"
L7	5+05.67		62.19	S88° 39' 34.19"W	
C11	5+67.86	175.00	274.89	N46° 20' 25.81"W	90°00'00"
L8	8+42.75		103.90	N1° 20' 25.81"W	
C12	9+46.65	225.00	356.88	N44° 06' 05.94"E	90°52'44"
L9	13+03.53		182.90	N89° 32' 17.70"E	
L10	14+86.43		316.25	N89° 32' 17.70"E	

RD4

Number	Station	Radius	Length	Line/Chord Direction	Delta Angle
L11	0+00.00		55.94	S83° 13' 33.26"E	
C13	0+55.94	250.00	140.29	S67° 09' 00.46"E	32°09'06"
C14	1+96.23	250.00	146.79	S67° 53' 44.54"E	33°38'34"
L12	3+43.03		187.10	S84° 43' 01.43"E	

RD5

Number	Station	Radius	Length	Line/Chord Direction	Delta Angle
L13	0+00.00		49.45	N52° 37' 54.84"W	

RD6


Number	Station	Radius	Length	Line/Chord Direction	Delta Angle
L14	0+00.00		47.63	N45° 24' 11.54"W	

RD7

Number	Station	Radius	Length	Line/Chord Direction	Delta Angle
L15	0+00.00		78.26	N51° 14' 49.74"E	

SYMBOL LEGEND

DESCRIPTION	PROPOSED	EXISTING
MINOR CONTOUR		
MAJOR CONTOUR		
LOT LINE		
WATERMAIN		
BUILDING SETBACK BOUNDARY		
PARCEL BOUNDARY LINE		
DRAINAGE AND UTILITY EXHIBITS		
CLUB AND GUTTER		
RIGHT-OF-WAY		
DRAINAGE WYCKENOUTS		
BACKYARD CATCHBASIN		
CATCHBASIN		
STORM SEWER MANHOLE		
FLARED END SECTION WORK-PAUP		
STORM STRUCTURE LANE		
SANITARY STRUCTURE LANE		
SANITARY SEWER MANHOLE		
HYDRANT		
GATE VALVE		
WELL		
DRAIN FLOW RELEASE ARROW		
EMERGENCY OVERTLOW WALL		
SOIL BORING LOCATION		
SALT PENE		
TREE PRESERVATION FENCE		
BARICADE		
SPOT ELEVATION		
TRICSPOT ELEVATION		
UTILITY POLE		
LIGHT POLE		
HANDICAP PARKING SPACE		



EXISTING UTILITIES SHOWN ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISING OUT OF HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL EXISTING UTILITIES.

DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE PARCELS	01	ERJ	08/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	08/14/14	STORM REVISIONS
CHECKED BY	03	ERJ	08/26/14	SHOW WETLAND B IMPACT
RSM				
DATE				
08/08/14				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Robert S. Molstad
 ROBERT S. MOLSTAD, P.E.
 Date: 08/08/14 Lic. No. 24728

ENGINEERS SURVEYORS
SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN. 55391 (952) 476-6000


CITY PROJECT NO. _____

LAKE ELMO, MINNESOTA


PRELIMINARY STREET PLAN
VILLAGE PARK PRESERVE
GWSA LAND DEVELOPMENT

FILE NO. 3120-047
ST1
ST5

EASTON VILLAGE



VILLAGE PARKWAY



EXISTING UTILITIES SHOWN ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISING OUT OF HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL EXISTING UTILITIES.

DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE PARCEL E	01	ERJ	08/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	08/13/14	STORM REVISIONS
CHECKED BY	03	ERJ	08/26/14	SHOW WETLAND & IMPACT
RSM				
DATE				
08/08/14				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Robert S. Molstad
 ROBERT S. MOLSTAD, P.E.
 Date: 08/08/14 Lic. No. 26478


SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN. 55391 (952) 478-8000

ENGINEERS
 PLANNERS


CITY PROJECT NO.
 LAKE ELMO, MINNESOTA

PRELIMINARY STREET PLAN
 VILLAGE PARK PRESERVE
 GWSA LAND DEVELOPMENT


FILE NO.
 3120-047
ST2
ST5



RD 6



RD 3



EXISTING UTILITIES SHOWN ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISING OUT OF HIS FAILURE TO EXACTLY LOCATE AND PREPARE ANY AND ALL EXISTING UTILITIES.

DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE PARCEL E	01	ERJ	08/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	08/18/14	STORM REVISIONS
CHECKED BY	03	ERJ	08/26/14	SHOW WETLAND B IMPACT
RSM				
DATE				
DATE				

USE (INCLUDING COPYING, DISTRIBUTION AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Robert S. Molstad
 ROBERT S. MOLSTAD, P.E.
 Date: 08/08/14 Lic. No. 24428


ENGINEERS
PLANNERS





SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN. 55391 (952) 476-6000

CITY PROJECT NO.
 LAKE ELMO, MINNESOTA

PRELIMINARY STREET PLAN
 VILLAGE PARK PRESERVE
 GWSA LAND DEVELOPMENT

FILE NO.
 3120-047
ST3
ST5





DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE PARCEL E	01	ERJ	08/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	08/14/14	STORM REVISIONS
CHECKED BY	03	ERJ	08/26/14	SHOW WETLAND B IMPACT
RSM				
DATE				
08/08/14				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.




Robert S. Molstad
 ROBERT S. MOLSTAD, P.E.
 Date: 08/08/14 Lic. No. 24428

ENGINEERS

PLANNERS

SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN. 55391 (952) 478-0000

CITY PROJECT NO.	PRELIMINARY STREET PLAN	FILE NO. 3120-047
	LAKE ELMO, MINNESOTA	ST4
	VILLAGE PARK PRESERVE	ST5
	GWSA LAND DEVELOPMENT	



DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE PARCELS	01	ERJ	08/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	08/14/14	STORM REVISIONS
CHECKED BY	03	ERJ	08/25/14	SHOW WETLAND B IMPACT
DATE				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Robert S. Molstad
 ROBERT S. MOLSTAD, P.E.
 Date: 08/08/14 Lic. No. 26478

SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN, 55391 (952) 478-8000


CITY PROJECT NO. _____

LAKE ELMO, MINNESOTA

PRELIMINARY STREET PLAN
VILLAGE PARK PRESERVE
GWSA LAND DEVELOPMENT

FILE NO. 3120-047
ST5
ST5





EXISTING UTILITIES SHOWN ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISING OUT OF HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL EXISTING UTILITIES.

DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE PARCEL E	01	ERJ	08/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	08/19/14	STORM REVISIONS
ERJ	03	ERJ	08/26/14	SHOW WETLAND & IMPACT
CHECKED BY				
RSM				
DATE				
08/08/14				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.


Robert S. Molstad
 ROBERT S. MOLSTAD, P.E.
 Date: 08/08/14 Lic. No. 24421

SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN, 55391 (952) 476-8000


CITY PROJECT NO.
 LAKE ELMO,
 MINNESOTA

PRELIMINARY UTILITY PLAN
VILLAGE PARK PRESERVE
GWSA LAND DEVELOPMENT

FILE NO.
 3120-047
UP1
UP6



PROJECT HOME PAGE NUMBER



EXISTING UTILITIES SHOWN ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISING OUT OF HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL EXISTING UTILITIES.

DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE PARCEL E	01	ERJ	08/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	08/14/14	STORM REVISIONS
ERJ	03	ERJ	08/20/14	SHOW WETLAND B IMPACT
CHECKED BY				
RSM				
DATE				
08/08/14				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Robert S. Molstad
ROBERT S. MOLSTAD, P.E.
Date: 08/08/14 Lic. No. 24428


ENGINEERS SURVEYORS PLANNERS

SATHRE-BERGQUIST, INC.
150 SOUTH BROADWAY WAYZATA, MN 55391 (952) 476-6000

CITY PROJECT NO.
LAKE ELMO, MINNESOTA

PRELIMINARY UTILITY PLAN
VILLAGE PARK PRESERVE
GWSA LAND DEVELOPMENT

FILE NO.
3120-047
UP2
UP6



EXISTING UTILITIES SHOWN ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISING OUT OF HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL EXISTING UTILITIES.

DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE PARCEL E	01	ERJ	08/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	08/14/14	STORM REVISIONS
CHECKED BY	03	ERJ	08/26/14	SHOW WETLAND & IMPACT
RSM				
DATE				
08/05/14				

USE (INCLUDING COPYING, DISTRIBUTION AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Robert S. Molstad
ROBERT S. MOLSTAD, P.E.
Date: 08/08/14 Lic. No. 26428

SATHRE-BERGQUIST, INC.
150 SOUTH BROADWAY WAYZATA, MN, 55391 (952) 478-0000

ENGINEERS
PLANNERS
DESIGNERS

CITY PROJECT NO.
LAKE ELMO, MINNESOTA

PRELIMINARY UTILITY PLAN
VILLAGE PARK PRESERVE
GWSA LAND DEVELOPMENT


FILE NO.
3120-047

UP3
UP6

SCALE IN FEET
0 25 50 100

PROJECT: Inmate-Audit-2014-01


EASTON VILLAGE



57.56

MANNING AVENUE NORTH (CSAH NO. 75)

PROPOSED IMPROVEMENTS
(BY OTHERS)



EXISTING UTILITIES SHOWN ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISING OUT OF HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL EXISTING UTILITIES.

DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE PARCEL E	01	ERJ	08/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	08/14/14	STORM REVISIONS
CHECKED BY	03	ERJ	08/20/14	SHOW WETLAND IMPACT
RSM				
DATE				
08/08/14				

USE (INCLUDING COPYING, DISTRIBUTION AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Robert S. Molstad
 ROBERT S. MOLSTAD, P.E.
 Date: 08/08/14 Lic. No. 24728





SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN. 55391 (952) 476-6000

CITY PROJECT NO.
 LAKE ELMO, MINNESOTA

PRELIMINARY UTILITY PLAN
 VILLAGE PARK PRESERVE
 GWSA LAND DEVELOPMENT

FILE NO.
 3120-047
 UP4
 UP6



EXISTING UTILITIES SHOWN AS AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISING OUT OF HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL EXISTING UTILITIES.

DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE PARCEL E	01	ERJ	08/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	08/14/14	STORM REVISIONS
CHECKED BY	03	ERJ	08/26/14	SHOW WETLAND B IMPACT
RSM				
DATE				
08/08/14				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Robert S. Molstad
 ROBERT S. MOLSTAD, P.E.
 Date: 08/08/14 Lic. No. 24742

CITY PROJECT NO. _____

SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN. 55391 (952) 478-6000

LAKE ELMO, MINNESOTA



PRELIMINARY UTILITY PLAN
 VILLAGE PARK PRESERVE
 GWSA LAND DEVELOPMENT

FILE NO. 3120-047
 UP5
 UP6

EXISTING MANNING
CONDITIONS



PROPOSED MANNING
IMPROVEMENTS



EXISTING UTILITIES SHOWN ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISING OUT OF HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL EXISTING UTILITIES.

DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE_PARCEL E	01	ERJ	08/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	08/14/14	STORM REVISIONS
ERJ	03	ERJ	08/26/14	SHOW WETLAND & IMPACT
CHECKED BY				
RSM				
DATE				
08/05/14				

USE (INCLUDING COPYING, DISTRIBUTION AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Robert S. Mclstad
 ROBERT S. MCLSTAD, P.E.
 Date: 08/08/14 Lic. No. 26428



SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN, 55391 (952) 476-8000

CITY PROJECT NO.
 LAKE ELMO,
 MINNESOTA

POND #1 SE OUTLET DETAIL
 VILLAGE PARK PRESERVE
 GWSA LAND DEVELOPMENT

FILE NO.
 3120-047
 UP6
 UP6

MILLER/ELI/BLAKE/RODOLPH




- CONSTRUCTION NOTES**
1. INSTALL SILT FENCE AS SHOWN ON PLAN, AS REQUIRED BY THE CITY OF LAKE ELMO OR DIRECTED BY THE ENGINEER.
 2. THE WATER QUALITY POND MUST BE EXCAVATED AT THE BEGINNING OF GRADING OPERATIONS TO PROVIDE TEMPORARY STORM WATER DETENTION DURING CONSTRUCTION. SAND AND SILT MUST BE REMOVED FROM THE POND AS NECESSARY DURING CONSTRUCTION AND AT THE COMPLETION OF THE PROJECT.
 3. BEGIN GRADING. INSTALL PERFORATED RISER PIPE IN PONDS WHEN POND GRADING IS COMPLETE. TEMPORARY DRAINAGE PIPE SHALL BE USED FOR INTERMEDIATE DRAINAGE DURING THE CONSTRUCTION PERIOD AS NECESSARY AND DIRECTED BY THE ENGINEER. INSTALL SILT FENCE AROUND EXCAVATED PONDS.
 4. INSPECT POND, SILT FENCE, AND ROCK ENTRANCE BERM AFTER ALL RAINFALL EVENTS AS REQUIRED BY THE NPOES PERMIT.
 5. LINE ALL PONDS WITH A MINIMUM 3" ORGANIC SOIL & SEED MIXES BETWEEN NWL AND 100 YR HW, WITH A WATER TOLERANT MIX, (OR AS NOTED).
 6. REMOVE PERFORATED RISER PIPE WHEN STORM SEWER AND OUTLET STRUCTURE FOR PONDS ARE INSTALLED.
 7. POND - 10:1 BENCH (1 FOOT) THEN 4:1 MAX.
 8. LO & WO PADS 3:1 MAX. ALL OTHER SLOPES 4:1 MAX (UNLESS NOTED).
 9. RESTORATION - 40 ACRES
 - A. RESTORE ALL DISTURBED AREAS WITH 4" TO 6" OF TOPSOIL, OR EXISTING ON-SITE ORGANIC MTRL.
 - B. SEED POND SLOPES AND DETENTION AREAS WITH MNDOT 310 OR BWSR P8 SEED MIX AT A RATE OF 100 LBS/ACRE AND FERTILIZE WITH 20-0-10 AT 100 LBS/ACRE. SEED WETLAND BUFFER AREAS WITH MNDOT 350-MESIC PRAIRIE (36.5 PLUS LBS/AC) OR BWSR 35-241 SEED MIX AND FERTILIZE WITH 20-0-10 AT 100 LBS/ACRE. (REFER TO WETLAND CREATION/BANKING PLAN FOR WTL AND SEED MIX REQUIREMENTS).
 - C. SEED ALL OTHER DISTURBED AREAS WITH MNDOT 350 AT A RATE OF 100 LBS/ACRE AND FERTILIZE WITH 20-0-10 AT 100 LBS/ACRE. (UNLESS OTHERWISE NOTED).
 - D. ONLY PHOSPHOROUS FREE FERTILIZER IS TO BE USED ON SITE.
 - E. MULCH WITH TYPE 1 AT A RATE OF 2 TONS/ACRE AND DISC ANCHOR IMMEDIATELY AFTER PLACEMENT. USE WOOLFIBER BLANKET ON ALL SLOPES 3:1 (FT) OR GREATER.
 - F. PLACE APPROVED STORM SEWER INLET PROTECTION IN OR AROUND ALL STORM SEWER INLETS AND MAINTAIN UNTIL STREET CONSTRUCTION IS COMPLETED. REFER TO CITY DETAIL S ST-22 & ST-23 FOR APPROVED DEVICES.
 - G. MAINTAIN ALL SILT FENCE UNTIL TURF HAS BEEN ESTABLISHED.
 - H. RESTORATION WORK WILL BE COMPLETED WITHIN 72 HOURS OF GRADING COMPLETION.
 10. GRADE BACK 3' FROM FACE OF ALL RETAINING WALLS.
 11. MAINTAIN TEMPORARY DRAINAGE ALONG EAST SIDE OF PROPERTY LINE.
 12. SILT FENCE - BEFORE GRADING - 5,760 LF.

- GENERAL NOTES:**
1. THE GRADING CONTRACTOR IS RESPONSIBLE FOR ALL STORM WATER INSPECTIONS ACCORDING TO THE MPCA STORM WATER PERMIT. THIS INCLUDES BOTH WEEKLY INSPECTIONS AND INSPECTIONS DONE AFTER A 0.5" RAIN EVENT. A COPY OF THE INSPECTION REPORT MUST BE EMAILED TO THE ENGINEER AND DEVELOPER ON A WEEKLY BASIS.
 2. THE CONTRACTOR SHALL PLACE INLET PROTECTION DEVICES IN ACCORDANCE WITH THE CITY OF LAKE ELMO DETAIL 51-22.51.23 FOR ALL STORM SEWER INLETS AND MAINTAIN THEM AS AN EFFECTIVE SILT CONTROL DEVICE. INLET PROTECTION SHALL BE REMOVED WHEN RESTORATION HAS BEEN ESTABLISHED.
 3. ALL RETAINING WALLS WILL REQUIRE A STRUCTURAL DESIGN, A BUILDING PERMIT & A FINAL INSPECTION REPORT.
 4. A 1'-2" CRUSHED ROCK ENTRANCE BERM SHALL BE PLACED AT THE SITE ENTRANCE, TO REPLACE SILT FENCE, AND MINIMIZE EROSION ON TO THE STREETS. THE ROCK BERMS SHALL BE THE WIDTH OF THE ENTRANCE AND 2 FEET HIGH WITH 4:1 SLOPES. (SEE DETAIL).
 5. THE CONTRACTOR SHALL MAINTAIN POSITIVE DRAINAGE AWAY FROM THE BUILDING PAD AND STREET AREAS THROUGHOUT CONSTRUCTION.
 6. THE CONTRACTOR SHALL ATTEMPT TO PREVENT SOIL MATERIALS FROM LEAVING THE SITE BY EROSION AND VEHICLE WHEEL TRACKING. HE SHALL BE RESPONSIBLE FOR CLEANING OF STREET, BOULEVARD AND UTILITY FACILITIES THAT RECEIVE ANY ERODED OR TRACKED SOIL MATERIAL OR OTHER CONSTRUCTION DEBRIS OR MATERIAL.
 7. EXISTING UTILITIES SHOWN ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISING OUT OF HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL EXISTING UTILITIES.
 8. BUILDING PADS ARE 6" DEEP, UNLESS OTHERWISE NOTED. THE FRONT AND REAR BUILDING PAD LINES ARE SHOWN ON THE PLAN. THE ENGINEER SHOULD BE CONTACTED IF THE CONTRACTOR HAS ANY QUESTIONS REGARDING BUILDING PADS.

24" Gas Pipeline as shown in D. No. 3975697

88 Feet Wide Gas Easement, Per D. No. 3540229, Modified to 85 ft. Per Doc. No. 897254



EXISTING UTILITIES SHOWN ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISING OUT OF HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL EXISTING UTILITIES.

DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE_PARCEL E	01	ERJ	08/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	08/14/14	STORM REVISIONS
CHECKED BY	03	ERJ	08/26/14	SHOW WETLAND & IMPACT
DATE				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.


Robert S. Molstad
 ROBERT S. MOLSTAD, P.E.
 Date: 08/08/14 Lic. No. 24728

SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN. 55391 (952) 476-6000

CITY PROJECT NO.	PRELIMINARY GRADING PLAN	FILE NO.
LAKE ELMO, MINNESOTA	VILLAGE PARK PRESERVE	3120-047
	GWSA LAND DEVELOPMENT	GP1
		GP5

LAKE ELMO VILLAGE

EASTON VILLAGE



24" Gas Pipeline as shown in Doc. No. 3979697



SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN. 55391 (652) 476-6000

CITY PROJECT NO.
 LAKE ELMO,
 MINNESOTA

PRELIMINARY GRADING PLAN
 VILLAGE PARK PRESERVE
 GWSA LAND DEVELOPMENT

FILE NO.
 3120-047
GP2
GP5


EXISTING UTILITIES SHOWN ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISING OUT OF HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL EXISTING UTILITIES.

DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE PARCEL E	01	ERJ	06/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	08/14/14	STORM REVISIONS
ERJ	03	ERJ	08/26/14	SHOW WETLAND B IMPACT
CHECKED BY				
RSM				
DATE				
06/08/14				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Robert S. Molstad
 ROBERT S. MOLSTAD, P.E.
 Date: 08/08/14 Lic. No. 26728



66 Foot Wide Gas Easement Per Doc. No. 384029, Modified to 86 feet per Doc. No. 882264

EXISTING UTILITIES SHOWN ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISING OUT OF HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL EXISTING UTILITIES.

DRAWING NAME	NO.	BY	DATE
BASE PARCEL E	01	ERJ	08/11/14
DRAWN BY	02	ERJ	08/15/14
CHECKED BY	03	ERJ	08/26/14
RSM			
DATE			
08/08/14			

REVISIONS
UTILITY VIEWPORT REVISIONS
STORM REVISIONS
SHOW WETLAND & IMPACT

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Robert S. Molstad
 ROBERT S. MOLSTAD, P.E.
 Date: 08/08/14 Lic. No. 26478

SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN. 55391 (952) 476-0000

ENGINEERING CONSULTANTS PLANNERS


CITY PROJECT NO.
 LAKE ELMO, MINNESOTA

PRELIMINARY GRADING PLAN
 VILLAGE PARK PRESERVE
 GWSA LAND DEVELOPMENT

FILE NO.
 3120-047
 GP3
 GP5


PROJECT NAME AND NUMBER

EASTON VILLAGE



MANNING AVENUE NORTH (CSAH NO. 75)

PROPOSED IMPROVEMENTS
(BY OTHERS)



EXISTING UTILITIES SHOWN ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISE OUT OF HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL EXISTING UTILITIES.

DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE PARCEL E	01	ERJ	05/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	05/15/14	STORM REVISIONS
CHECKED BY	03	ERJ	06/26/14	SHOW WETLAND B IMPACT
RSM				
DATE				
05/08/14				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Robert S. Molstad
 ROBERT S. MOLSTAD, P.E.
 Date: 05/08/14 Lic. No. 26421




SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN. 55391 (952) 476-6000

CITY PROJECT NO.
 LAKE ELMO, MINNESOTA

PRELIMINARY GRADING PLAN
 VILLAGE PARK PRESERVE
 GWSA LAND DEVELOPMENT

FILE NO.
 3120-047
 GP4
 GP5

PROJECT NAME: EASTON VILLAGE



EXISTING UTILITIES SHOWN ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISING OUT OF HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL EXISTING UTILITIES.

DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE PARCEL E	01	ERJ	08/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	08/14/14	STORM REVISIONS
CHECKED BY	03	ERJ	08/26/14	SHOW WETLAND & IMPACT
RSM				
DATE				
08/08/14				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Robert S. Molstad
 ROBERT S. MOLSTAD, P.E.
 Date: 08/08/14 Lic. No. 24424


PROPOSED IMPROVEMENTS (BY OTHERS)

SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN. 55391 (952) 478-8000

CITY PROJECT NO.
 LAKE ELMO, MINNESOTA

PRELIMINARY GRADING PLAN
 VILLAGE PARK PRESERVE
 GWSA LAND DEVELOPMENT

FILE NO.
 3120-047
GP5
GP5



PROJECT NAME: VILLAGE PARK PRESERVE



- ROCK ENTRANCE BERM
- SILT FENCE
- POST GRADING SILT FENCE
- BIO-ROLL
- CONCRETE WASHOUT
- INLET PROTECTION
- WOODFIBER BLANKET

24" Gas Pipeline as shown in D - No. 08790877

66 Foot Wide City Easement Per D.C. No. 254029, Modified to 66' 14" per D.C. No. 052264

EASTON VILLAGE

EXISTING UTILITIES SHOWN ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISING OUT OF HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL EXISTING UTILITIES.

DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE PARCELS	01	ERJ	08/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	08/14/14	STORM REVISIONS
CHECKED BY	03	ERJ	08/26/14	SHOW WETLAND & IMPACT
RSM				
DATE				
08/08/14				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Robert S. Molstad
 ROBERT S. MOLSTAD, P.E.
 Date: 08/08/14 Lic. No. 24728



SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN. 55391 (952) 476-6000


CITY PROJECT NO.
 LAKE ELMO, MINNESOTA

PRELIMINARY EROSION CONTROL PLAN & TREE SURVEY
 VILLAGE PARK PRESERVE
 GWSA LAND DEVELOPMENT

FILE NO.
 3120-047
 EC1
 EC3



-  ROCK ENTRANCE BERM
-  SILT FENCE
-  POST GRADING SILT FENCE
-  BIO-ROLL
-  CONCRETE WASHOUT
-  INLET PROTECTION
-  WOODFIBER BLANKET



24" Gas Pipeline as shown in Doc. No. 3979697

EASTON VILLAGE

Stormwater Pond #4SE
NWI - 912.5
Hwt - 916.0

Stormwater Pond #3SE
NWI - 912.0
Hwt - 918.0

Village Parkway

RD03

EXISTING UTILITIES SHOWN ARE SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ANY AND ALL EXISTING UTILITIES BEFORE COMMENCING WORK. HE AGREES TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES ARISING OUT OF HIS FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL EXISTING UTILITIES.

DRAWING NAME	NO.	BY	DATE	REVISIONS
BASE PARCEL E	01	ERJ	09/11/14	UTILITY VIEWPORT REVISIONS
DRAWN BY	02	ERJ	09/14/14	STORM REVISIONS
CHECKED BY	03	ERJ	09/26/14	SHOW WETLAND & IMPACT
RSM				
DATE				
06/08/14				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Robert S. Molstad
ROBERT S. MOLSTAD, P.E.
Date: 09/08/14 Lic. No. 24428




SATHRE-BERGQUIST, INC.
150 SOUTH BROADWAY WAYZATA, MN. 55391 (952) 476-6000


CITY PROJECT NO.

LAKE ELMO,
MINNESOTA

PRELIMINARY EROSION CONTROL PLAN & TREE SURVEY
VILLAGE PARK PRESERVE
GWSA LAND DEVELOPMENT

FILE NO.
3120-047
EC2
EC3





24" Gas Pipeline as shown in Doc. No. 3979697

66 Foot Wide Gas Easement Per Doc. No. 384029, Modified to 86 feet per Doc. No. RR2264

Tree #	Tree Species	Condition	Total Cal. In.	Removed	
				Cal. In.	Tree #
746	Boxelder	Fair	23.0		
747	Boxelder	Fair	27.0		
748	Hackberry	Fair	10.0		
749	Boxelder	Fair	22.0		
750	Boxelder	Fair	34.0		
751	Cherry, black	Fair	8.0		
752	Boxelder	Fair	12.0		
753	Boxelder	Fair	13.0		
754	Oak, bur	Fair	26.0		
755	Boxelder	Fair	16.0	16.0	
756	Boxelder	Fair	16.0	16.0	
757	Ash, green	Fair	17.0	17.0	
758	Ash, green	Fair	12.0		
759	Boxelder	Fair	14.0		
760	Boxelder	Fair	15.5		
761	Ash, green	Fair	12.0		
762	Boxelder	Fair	13.0	13.0	
763	Ash, green	Fair	14.0		
764	Ash, green	Fair	21.0	21.0	
765	Oak, bur	Good	28.0		
766	Ash, green	Fair	36.0		
767	Oak, bur	Fair	36.0		
768	Ash, green	Fair	15.0		
769	Boxelder	Fair	13.0		
770	Boxelder	Fair	12.0		
Total Caliper Inches			467.5		
Exempt Caliper Inches			100.0		
Net Caliper Inches			367.5		
Removed Caliper Inches			83.0		
Percent Removed			22.6%		
Percent Saved			77.4%		

- DENOTES TREE SAVED
- DENOTES TREE REMOVED
- DENOTES TREE EXEMPT

DRAWING NAME	NO.	BY	DATE	REVISIONS
TREE SURVEY				
DRAWN BY		ERJ		
CHECKED BY		RSM		
DATE			09/02/14	

USE (INCLUDING COPYING, DISTRIBUTION AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT SATHRE-BERGQUIST, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY SATHRE-BERGQUIST, INC. OF ALL RESPONSIBILITY. SATHRE-BERGQUIST, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

I HEREBY CERTIFY THAT THIS PLAN OR SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

Nathan Herman
 NATHAN HERMAN, P.E.
 Date: 07/22/14 Lic. No. 24428

SATHRE-BERGQUIST, INC.
 150 SOUTH BROADWAY WAYZATA, MN. 55391 (952) 478-6000

CITY PROJECT NO.
LAKE ELMO, MINNESOTA

TREE SURVEY
VILLAGE PARK PRESERVE
GWSA LAND DEVELOPMENT

FILE NO.
 3120-047
TS1
TS1



REQUIRED TREE PLANTING LEGEND

KEY	COMMON NAME	BOTANICAL NAME	QUANTITY	SIZE	NOTES
TREES					
AL	Linden 'Redmond'	<i>Tilia americana</i> 'Redmond'	9	2 5" BB	straight single leader
HA	Hackberry	<i>Celtis occidentalis</i>	12	2 5" BB	straight single leader
HL	Honey Locust 'Skyline'	<i>Gleditsia tricanthos</i> var. <i>inermis</i> 'Skyline'	12	2 5" BB	straight single leader
PE	Princeton Elm	<i>Ulmus americana</i> 'Princeton'	11	2 5" BB	straight single leader
RB	River Birch	<i>Betula nigra</i>	16	2 5" BB	multi-stem
RM	Red Maple	<i>Acer rubrum</i>	16	2 5" BB	straight single leader
RO	Red Oak	<i>Quercus rubra</i>	19	2 5" BB	straight single leader
SM	Sugar Maple	<i>Acer saccharum</i>	11	2 5" BB	straight single leader
SO	Swamp Oak	<i>Quercus bicolor</i>	5	2 5" BB	straight single leader
WO	White Oak	<i>Quercus alba</i>	11	2 5" BB	straight single leader
EVERGREENS					
BH	Black Hills Spruce	<i>Picea glauca densata</i>	30	6" BB	
NP	Norway Pine	<i>Pinus resinosa</i>	28	6" BB	
SN	Norway Spruce	<i>Picea abies</i>	38	6" BB	
WP	White Pine	<i>Pinus strobus</i>	28	6" BB	
			Total	255	

TREE PLANTING REQUIREMENTS = 5 TREES / ACRE DISTURBED
 51 ACRES DISTURBED = 255 TREES

STREET FRONTAGE TREE PLANTING LEGEND

KEY	COMMON NAME	BOTANICAL NAME	QTY.	SIZE	NOTES
TREES					
AL	Greenspire Linden	<i>Tilia cordata</i> 'Greenspire'	34	2 5" BB	Straight single leader
AM	Autumn Blaze Maple	<i>Acer x freemanii</i> 'Jeffersred'	25	2 5" BB	Straight single leader
HA	Hackberry	<i>Celtis occidentalis</i>	39	2 5" BB	Straight single leader
HL	Honey Locust	<i>Gleditsia tricanthos</i> var. <i>inermis</i> 'Imperial'	29	2 5" BB	Straight single leader
PE	Princeton Elm	<i>Ulmus americana</i> 'Princeton'	14	2 5" BB	Straight single leader
RM	Red Maple	<i>Acer rubrum</i>	32	2 5" BB	Straight single leader
RO	Red Oak	<i>Quercus rubra</i>	32	2 5" BB	Straight single leader
SM	Sugar Maple	<i>Acer saccharum</i>	27	2 5" BB	Straight single leader
WO	White Oak	<i>Quercus alba</i>	23	2 5" BB	Straight single leader
			TOTAL	255	

MN DOT 250 MIX



Common Name	Scientific Name	% Mix	Seed/sq ft	Rate / acre
Slender Wheat Grass	<i>Agropyron trachycaudum</i>	4.0	7.1	2.8 lb
Redtop	<i>Agrostis alba</i>	3.0	233.7	2.1 lb
Smooth Bromegrass	<i>Bromus inermis</i>	14.0	42.4	9.8 lb
Perennial Rye	<i>Lolium perenne</i>	21.0	81.0	14.7 lb
alfalfa (Creeping)	<i>Medicago sativa</i>	6.0	21.6	4.2 lb
Switchgrass	<i>Panicum virgatum</i>	3.0	10.8	2.1 lb
Timothy	<i>Phleum pratense</i>	3.0	56.3	2.1 lb
Canada Bluegrass	<i>Poa compressa</i>	14.0	539.9	9.8 lb
Kentucky Bluegrass	<i>Poa pratensis</i>	29.0	648.7	20.3 lb
White Clover	<i>Trifolium</i>	3.0	37.8	2.1 lb

Seeding Rate: 70 lb / Acre

NOTE:
 ALL TREES SHALL HAVE A MINIMUM DEPTH OF 6" HARDWOOD BARK MULCH RING AROUND THE BASE OF THE TREE.

MINIMUM OF 2 ROWS OF SOD BEHIND CURB.
 AREAS WITH SIDEWALKS SHALL BE SODDED FROM BACK OF CURB TO SIDEWALK.

ALL RESIDENTIAL LOTS SHALL BE TEMPORARILY SEEDED WITH MN DOT 250 SEED MIX.
 ALL OUTLOTS SHALL BE PERMANENTLY SEEDED WITH MN DOT 250 SEED MIX WITH EXCEPTION TO OUTLOTS TO BE SODDED AS SHOWN IN PLAN.



DRAWING NAME	NO.	BY	DATE	REVISIONS
Landscape Plan				
DRAWN BY				
CHECKED BY				
DATE				



USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT NORBY & ASSOCIATES LANDSCAPE ARCHITECTS, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY NORBY & ASSOCIATES LANDSCAPE ARCHITECTS, INC. OF ALL RESPONSIBILITY. NORBY & ASSOCIATES LANDSCAPE ARCHITECTS, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.

Norby & Associates
 Landscape Architects, Inc.
 100 East Second Street Chaska, MN 55318 (952) 361-6644

CITY PROJECT NO. _____
LAKE ELMO, MINNESOTA

PRELIMINARY LANDSCAPE PLAN
PARCEL E
SCHILTGEN FARMS
GWSA LAND DEVELOPMENT

FILE NO. 3120-047
 LP1
 LP4



DRAWING NAME	NO.	BY	DATE	REVISIONS
Landscape Plan				
DRAWN BY				
CHECKED BY				
DATE				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT NORBY & ASSOCIATES LANDSCAPE ARCHITECTS, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY NORBY & ASSOCIATES LANDSCAPE ARCHITECTS, INC. OF ALL RESPONSIBILITY. NORBY & ASSOCIATES LANDSCAPE ARCHITECTS, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.




Norby & Associates
 Landscape Architects, Inc.
 100 East Second Street • Chaska, MN 55318 • (952) 361-0644

CITY PROJECT NO.
LAKE ELMO,
MINNESOTA

PRELIMINARY LANDSCAPE PLAN
PARCEL E
SCHILTGEN FARMS
GWSA LAND DEVELOPMENT

FILE NO.
 3120-047
LP2
LP4



DRAWING NAME	NO.	BY	DATE	REVISIONS
Landscape Plan				
DRAWN BY:				
CHECKED BY:				
DATE				
08/07/14				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT NORBY & ASSOCIATES LANDSCAPE ARCHITECTS, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY NORBY & ASSOCIATES LANDSCAPE ARCHITECTS, INC. OF ALL RESPONSIBILITY. NORBY & ASSOCIATES LANDSCAPE ARCHITECTS, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.



Norby & Associates
 Landscape Architects, Inc.
 100 East Second Street Chaska, MN 55318 (952) 361-0644

CITY PROJECT NO.
 LAKE ELMO,
 MINNESOTA

PRELIMINARY LANDSCAPE PLAN
 PARCEL E
 SCHILTGEN FARMS
 GWSA LAND DEVELOPMENT

FILE NO.
 3120-017
 LP4
 LP4



REQUIRED TREE PLANTING LEGEND

KEY	COMMON NAME	BOTANICAL NAME	QUANTITY	SIZE	NOTES
TREES					
AL	Linden Redmond	<i>Tilia americana 'Redmond'</i>	9	2 5" BB	straight single leader
HA	Hackberry	<i>Celtis occidentalis</i>	12	2 5" BB	straight single leader
HL	Honey Locust 'Skyline'	<i>Gleditsia tricanthos var. inermis 'Skyline'</i>	12	2 5" BB	straight single leader
PE	Princeton Elm	<i>Ulmus americana 'Princeton'</i>	11	2 5" BB	straight single leader
RB	River Birch	<i>Betula nigra</i>	16	2 5" BB	multi-stem
RM	Red Maple	<i>Acer rubrum</i>	16	2 5" BB	straight single leader
RO	Red Oak	<i>Quercus rubra</i>	19	2 5" BB	straight single leader
SM	Sugar Maple	<i>Acer saccharum</i>	11	2 5" BB	straight single leader
SO	Swamp Oak	<i>Quercus bicolor</i>	5	2 5" BB	straight single leader
WO	White Oak	<i>Quercus alba</i>	11	2 5" BB	straight single leader
EVERGREENS					
BH	Black Hills Spruce	<i>Picea glauca densata</i>	39	6" BB	
NP	Norway Pine	<i>Pinus resinosa</i>	28	6" BB	
SN	Norway Spruce	<i>Picea abies</i>	28	6" BB	
WP	White Pine	<i>Pinus strobus</i>	28	6" BB	
			Total	255	

TREE PLANTING REQUIREMENTS = 5 TREES / ACRE DISTURBED
 51 ACRES DISTURBED = 255 TREES

STREET FRONTAGE TREE PLANTING LEGEND

KEY	COMMON NAME	BOTANICAL NAME	QTY.	SIZE	NOTES
TREES					
AL	Greenspire Linden	<i>Tilia cordata 'Greenspire'</i>	34	2 5" BB	Straight single leader
AM	Autumn Blaze Maple	<i>Acer x freemanii 'Jeffersred'</i>	25	2 5" BB	Straight single leader
HA	Hackberry	<i>Celtis occidentalis</i>	39	2 5" BB	Straight single leader
HL	Honey Locust	<i>Gleditsia tricanthos var. inermis 'imperial'</i>	29	2 5" BB	Straight single leader
PE	Princeton Elm	<i>Ulmus americana 'Princeton'</i>	14	2 5" BB	Straight single leader
RM	Red Maple	<i>Acer rubrum</i>	32	2 5" BB	Straight single leader
RO	Red Oak	<i>Quercus rubra</i>	32	2 5" BB	Straight single leader
SM	Sugar Maple	<i>Acer saccharum</i>	27	2 5" BB	Straight single leader
WO	White Oak	<i>Quercus alba</i>	23	2 5" BB	Straight single leader
			TOTAL	255	

MN DOT 250 MIX



Common Name	Scientific Name	% Mix	Seed/sq ft	Rate / acre
Slender Wheat Grass	<i>Agropyron trachycaulum</i>	4.0	7.1	2.8 lb
Redtop	<i>Agrostis alba</i>	3.0	233.7	2.1 lb
Smooth Bromegrass	<i>Bromus inermis</i>	14.0	32.4	9.8 lb
Perennial Rye	<i>Lolium perenne</i>	21.0	81.0	14.7 lb
Alfalfa (Creeping)	<i>Medicago sativa</i>	6.0	21.6	4.2 lb
Switchgrass	<i>Panicum virgatum</i>	3.0	10.8	2.1 lb
Timothy	<i>Phleum pratense</i>	3.0	56.3	2.1 lb
Canada Bluegrass	<i>Poa compressa</i>	14.0	539.9	9.8 lb
Kentucky Bluegrass	<i>Poa pratensis</i>	29.0	648.7	20.3 lb
White Clover	<i>Trifolium</i>	3.0	37.8	2.1 lb

Seeding Rate: 70 lb / acre

NOTE:
 ALL TREES SHALL HAVE A MINIMUM DEPTH OF 6" HARDWOOD BARK MULCH RING AROUND THE BASE OF THE TREE.

MINIMUM OF 2 ROWS OF SOD BEHIND CURB.
 AREAS WITH SIDEWALKS SHALL BE SODDED FROM BACK OF CURB TO SIDEWALK.

ALL RESIDENTIAL LOTS SHALL BE TEMPORARILY SEEDED WITH MN DOT 250 SEED MIX.
 ALL OUTLOTS SHALL BE PERMANENTLY SEEDED WITH MN DOT 250 SEED MIX WITH EXCEPTION TO OUTLOTS TO BE SODDED AS SHOWN IN PLAN.



DRAWING NAME	NO.	BY	DATE	REVISIONS
Landscape Plan				
DRAWN BY				
CHECKED BY				
DATE				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT NORBY & ASSOCIATES LANDSCAPE ARCHITECTS, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY NORBY & ASSOCIATES LANDSCAPE ARCHITECTS, INC. OF ALL RESPONSIBILITY. NORBY & ASSOCIATES LANDSCAPE ARCHITECTS, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.




Norby & Associates
 Landscape Architects, Inc.
 100 East Second Street Chaska, MN 55318 (952) 361-0644

CITY PROJECT NO.
 LAKE ELMO,
 MINNESOTA

PRELIMINARY LANDSCAPE PLAN
 PARCEL E
 SCHILTGEN FARMS
 GWSA LAND DEVELOPMENT


FILE NO.
 3120-047
 LP1
 LP4



1 SECTION LOOKING EAST FROM McLEOD PROPERTY
5 SCALE: 1"=20'



2 30TH PERIMETER SCREENING SECTION
5 SCALE: 1"=20'



2 30TH PERIMETER SCREENING SECTION CONTINUED
5 SCALE: 1"=20'

DRAWING NAME	NO.	BY	DATE	REVISIONS
DRAWN BY				
CHECKED BY				
DATE				

USE (INCLUDING COPYING, DISTRIBUTION, AND/OR CONVEYANCE OF INFORMATION) OF THIS PRODUCT IS STRICTLY PROHIBITED WITHOUT NORBY & ASSOCIATES LANDSCAPE ARCHITECTS, INC.'S EXPRESS WRITTEN AUTHORIZATION. USE WITHOUT SAID AUTHORIZATION CONSTITUTES AN ILLEGITIMATE USE AND SHALL THEREBY INDEMNIFY NORBY & ASSOCIATES LANDSCAPE ARCHITECTS, INC. OF ALL RESPONSIBILITY. NORBY & ASSOCIATES LANDSCAPE ARCHITECTS, INC. RESERVES THE RIGHT TO HOLD ANY ILLEGITIMATE USER OR PARTY LEGALLY RESPONSIBLE FOR DAMAGES OR LOSSES RESULTING FROM ILLEGITIMATE USE.



Norby & Associates
Landscape Architects, Inc.
100 East Second Street Chaska, MN 55318 (952) 361-0644

CITY PROJECT NO.
LAKE ELMO, MINNESOTA

LANDSCAPE PERIMETER SECTIONS
PARCEL E
SCHILTGEN FARMS
GWSA LAND DEVELOPMENT

FILE NO.
3120-047
LP5
LP5

**CITY OF LAKE ELMO
WASHINGTON COUNTY, MINNESOTA**

RESOLUTION NO. 2014-60

*RESOLUTION APPROVING AN AMENDMENT TO THE CITY OF LAKE ELMO
COMPREHENSIVE PLAN CHANGING THE FUTURE LAND USE DESIGNATION OF THE
HOLLIDAY PARCEL LOCATED IN THE VILLAGE PLANNING AREA*

WHEREAS, the City of Lake Elmo has established a Comprehensive Plan that provides a compilation of background data, policy statements, standards, and maps, which help to guide the future physical, social, and economic development of the City; and

WHEREAS, GWSA Land Development, LLC, 10850 Old County Road 15, Suite 200, Plymouth, MN, ("Applicant") has submitted an application to the City of Lake Elmo ("City") to amend the Lake Elmo Comprehensive Plan, a copy of which is on file in the City Planning Department; and

WHEREAS, the request to amend the Comprehensive Plan was submitted along with a Sketch Plan for a proposed single-family residential subdivision in the southeast portion of the Village Planning Area; and

WHEREAS, the Lake Elmo Planning Commission held a public hearing on June 30, 2014 to consider the request to amend the Comprehensive Plan; and

WHEREAS, on June 30, 2014, the Lake Elmo Planning Commission unanimously adopted a motion to recommend that the City Council approve the request to amend the Comprehensive Plan; and

WHEREAS, the City Council reviewed the recommendation of the Planning Commission and the proposed amendment to the Comprehensive Plan at a meeting on July 15, 2014;

NOW, THEREFORE, based upon the testimony elicited and information received, the City Council makes the following:

FINDINGS

- 1) That the Applicant has submitted a request to amend the Comprehensive Plan in accordance with the procedures as established by the Lake Elmo Planning Department and Lake Elmo Planning Commission.
- 2) That the request is to amend the Future Land Use Map (Map 3-3 in Chapter III - *Land Use Plan*) and Village Planned Land Use Map (Map 3-5 in Chapter III - *Land Use Plan*) in the Lake Elmo Comprehensive Plan, and to specifically change the future land use

designation a parcel of land located immediately west of Manning Avenue North (CSAH 15) and immediately north of 30th Street North (PID 13.029.21.44.0002) from RAID - Rural Area Development to V-LDR - Village Urban Low Density Residential.

- 3) That the Comprehensive Plan Amendment will apply to property legally described in the attached Exhibit "A".
- 4) That the subject property associated with the Comprehensive Plan Amendment request is currently located within the City's sanitary sewer service area.
- 5) That the proposed amendment will allow for the private market to complete the construction of the Village Parkway minor collector road, a critical transportation improvement needed to serve the upcoming growth and development and increased projected traffic volumes within the Village Planning Area.
- 6) That the area impacted by the proposed amendment is relatively small, and that the potential increase in residential units associated with the amendment is not inconsistent with the projected levels of planned growth and development in the Village Area under the Village Land Use Plan.

NOW, THEREFORE, BE IT RESOLVED, that based on the foregoing, the Lake Elmo City Council hereby approves the Applicant's request to amend the Lake Elmo Comprehensive Plan, subject to and contingent upon the following:

- 1) Submission of the Comprehensive Plan Amendment to the Metropolitan Council and the receipt of formal notification from the Metropolitan Council that its review has been completed and approved.
- 2) As part of the preparation of Preliminary Plans for the Village Preserve South subdivision, the applicant shall prepare a screening plan along the western boundary of the Holliday parcel adjacent to the Meleod parcel that effectively buffers the proposed residential subdivision from the rural single family lot to the west.

Passed and duly adopted this 15th day of July 2014 by the City Council of the City of Lake Elmo, Minnesota.


Mike Pearson, Mayor

ATTEST:



Adam Bell, City Clerk

EXHIBIT A

Legal Description (PID 13.029.21.44.0002)

The South 498.6 feet of the South Half of the Southeast Quarter (S1/2 of S1/4); Section Thirteen (13), Township Twenty Nine North (29N.), Range Twenty-one West (21W.); except the West 1273.0 feet of the South Half of the Southeast Quarter of said Section Thirteen (13). And excepting therefrom that portion of the above tract conveyed to the County of Washington by that certain Quit Claim Deed dated March 30, 1987, and filed of record in the Office of the Washington County Recorder on April 2, 1987 as Document No. 535377.

perimeters, including the storm sewer outfall pipe south of 30th Street and the existing watermain along 30th street.

- Grading contours must be fully completed at all Plat perimeters.
- Overland Emergency Overflows (EOFs) must be provided throughout the grading plan to facilitate a complete review of the grading plan and storm water flood protection for storm water ponds and localized low points.
- Stormwater facility maintenance access roads are not shown on the plans.

GRADING PLAN

- The grading plan is substantially complete however some contours remain incomplete near the plat perimeter. All contours must be completed to demonstrate a drainage design that does not negatively impact adjacent properties.
- Additional plan review is necessary once EOFs are provided to review for adequate flood protection for each adjacent lot. It appears that 8-10 lots have low floor elevations that do not meet the 2 feet of freeboard above the pond HWLs or 1 foot above an adjacent EOF.
- The HWL for Infiltration Area 1SE encroaches into Lot 1, Block 1. The HWL area must be fully contained within an Outlot dedicated to the City.
- The HWL for Stormwater Pond 1SE encroaches into the 30th Street R/W. The HWL area must be fully contained within an Outlot dedicated to the City and may not encroach the existing City R/W.
- Maintenance access roads meeting City Standards must be provided to each Stormwater pond and infiltration basin. Plan revisions are needed to provide adequate maintenance access to all storm water facilities. Access must be accommodated without impacts to the proposed infiltration benches.
- Stormwater Pond designs do not meet the City requirements, exceeding the maximum depth allowed of 10 feet. Additional design configuration concerns include maximum side slopes, maintenance of the infiltration bench, narrow constrictions within the ponds, and long term water levels.
- Additional catch basins are needed along Road 3 to meet maximum curb runs of 350 feet.

STORMWATER MANAGEMENT

- The site plan is dependent upon and subject to a storm water management plan meeting State, VBWD and City rules and regulations. Storm water facilities proposed as part of the site plan to meet VBWD permitting requirements must be constructed in accordance with the City Engineering Design Standards Manual available on the City website.
- The Stormwater model should be revised as documented in the attached EOR review memorandum and the Stormwater facilities revised accordingly.
 - Adjust assumed CN runoff coefficients and account for on-site depressional areas.
 - Provide additional supporting documentation for assumed infiltration rates and adjust to lower rates as needed.
 - Provide additional documentation to demonstrate the feasibility of the proposed new outlet and lowering of the outlet invert along Manning Avenue.
 - Update the model to include turn lanes improvements.
 - Update water quality value in table.

MUNICIPAL WATER SUPPLY

- Municipal water supply is available at the Reid Park lift station site and along 30th Street N. Connections to both locations will be required and have been shown on the Preliminary Plans.
- Watermain alignment will need to be revised as part of the final construction plans to better align within the paved street surfaces.
- Watermain stubs to adjacent property and pipe oversizing will continue to be reviewed by City staff as the development progresses forward and oversizing routes may need to be changed as part of the final

construction plans. Watermain oversizing is paid by the City as a reimbursement addressed within the development agreement.

- Hydrant and system valve locations will be reviewed with the Fire Chief and Public Works as part of the final construction plans.

MUNICIPAL SANITARY SEWER

- Municipal sanitary sewer is available at the Reid Park lift station site. The applicant is responsible to extend the municipal sanitary sewer to the development site at developers cost.
- To serve the property to the south, the invert at the 30th Street location must be at 905. This is required to remain responsive to future private ISTS system failures.
- A review of alternative sewer alignments and pipe oversizing was previously completed by City staff and provided to the applicant for input. The preliminary plans show a pipe configuration that is not consistent with the staff plan recommendation.
- Additional manholes will need to be incorporated in the plans to improve the street centerline alignment for the sanitary sewer and allow watermain at a 10 foot offset to remain within the paved street surface.
- Sanitary sewer pipe stubs to adjacent property and pipe oversizing will continue to be reviewed by City staff as the development progresses forward. Revisions may need to be incorporated as part of the final construction plans. Sewer pipe oversizing has been accounted for through the Village East Trunk Sanitary Sewer project. Therefore, the sewer pipe oversizing must be installed at no cost to the City.

RESIDENTIAL STREETS

- All streets must be designed to meet the City's Engineering Design Standards including R/W width, street width and cul-de-sac radii. The plans appear to substantially conform to this requirement.
- The street grades and profiles must be adjusted to meet the minimum K-value of 37 for vertical sag curves.
- The eyebrow designs for Roads 5, 6 and 7 propose a unique design. The roadway geometry requires additional review to ensure adequate pavement width and turning radius for emergency and maintenance vehicles. Turning templates must be submitted.
- The geometry for Road 5 requires particular attention to avoid conflicts along the higher volume roadway of Village Parkway. Road 5 should be shifted further north to align the south curb with Road 2. This would provide additional southbound left turn lane length for Village Parkway.

VILLAGE PARKWAY (NEIGHBORHOOD COLLECTOR STREET)

- Village Parkway will serve as a neighborhood collector for the new development in the southeastern Village area, essentially becoming the primary access in and out of the future neighborhoods. Obtaining increased mobility from a typical residential street will be necessary to accommodate the new growth while providing additional access and circulation into and out of the Village Downtown. Between State Highway 5 and the UP Railroad, Village Parkway will provide parking along one or both sides of the street to accommodate the mixed use development planned for the west side of the collector road. South of the UP Railroad the street will be posted as "No Parking".
- Village Parkway must be constructed according to the Village Parkway design standards and typical section as prepared by City staff. The street design must also meet Municipal State Aid design standards for an urban collector with ADT < 10,000; 35 mph design speed. The projected 2030 ADT is 5,800. The City typical section must be placed on the Preliminary Street Plans.
- The access management guidelines for Village Parkway must be established by the City and carefully planned out along its entire corridor from 30th Street to State Highway 5. Road 5 has been placed roughly 300 feet from 30th Street. A 330 foot access spacing is recommended. The additional 30 feet would help to provide additional turn lane length along Village Parkway.
- Right and left turn lanes are required along 30th Street when the Village Parkway intersection is constructed. The Preliminary Plans should be revised to provide a turn lane Plan Sheet to detail the turn

lane dimensions, including pavement widths, lane widths, turn lane lengths and tapers for staff review. It appears that the proposed turn lanes will need to be lengthened to meet typical turn lane design standards.

- The street grades and profiles must be adjusted along Village Parkway to meet the minimum K-value of 49 for vertical sag curves and minimum K-value of 29 for vertical crest curves. In addition, street grade changes along Village Parkway should be minimized and softened (not using minimum standards with every adjustment). The proposed profile must be revised to reduce the vertical curves to avoid a roller coaster effect along this high volume roadway. Street alignment transitions must be revised to rely on minimums only when necessary.
- The minimum horizontal curve radius for Village Parkway is 375 feet. C1 is currently proposed with a 250 foot radius.

Date | 9/3/2014

To | Jack Griffin

Contact info | Lake Elmo

cc |

Contact info |

cc |

Contact info |

From | Brett H. Emmons, Jay Hill

Contact info | EOR

Contact info |

Regarding | Lake Elmo, Village Park Preserve Development – Respond to City's List of Stormwater Review Issues

The information in these review comments are based on review of the following stormwater issues, per the city's request:

- Stormwater model input assumptions.
- Upstream runoff properly accounted for, including the pond discharge from Easton Village.
- Stormwater routing management is a workable plan for the area. The system must be able to accommodate the Downtown Village drainage.
- Flood protection (HWLs and Emergency overflows), including recommendations.
- Pond configurations and depths from the city's long term ownership and maintenance perspective (i.e. the deep storm water pond along Manning).

Documents submitted for the development review include:

- Preliminary Plan Set for Street, Utility, Grading, Landscape, and Drainage Area Plans, by Sathre-Bergquist, dated 8/8/14
- Stormwater Management Plan including 3 soil borings, by Sathre-Bergquist, dated 8/7/14

Stormwater Management and Stormwater BMPs:

1. CN and Runoff Assumptions – Proposed existing conditions (predevelopment) CNs appear too high and on-site depressional storage is not accounted for, thus providing a less conservative standard/target for their postdevelopment design.

Discussion: Predevelopment CNs are listed at 69 for agricultural areas (compared to post-development CNs of 74). The CN of 69 for existing conditions is high for the low runoff character of the existing lands. Also, observed runoff during rain events indicates that there is not much runoff until large events are experienced and/or snowmelt. Assuming higher predevelopment CNs leads to less conservative assumptions and reduced standards for peak rate control. For example, note that compacted yard/urban lawns are listed as CN 61 in post-development (much lower than existing CN of 69). Typically we would require a CN of 58 for predevelopment conditions to ensure

conservative assumptions for hydrologic routing and flood control. Areas in the model subcatchments for the open water pond with CNs of 100 do not appear in the model and should be included. On-site depressional storage is not accounted for in existing conditions and should be included.

2. Infiltration Assumptions – The assumed infiltration rate of 0.5 in/hr may be too high and is inconsistently applied and presented in the report and models.

Discussion: The assumed infiltration rates do not appear to be consistent between the models (HydroCAD and P8) and the narrative (Report Summary) of the Stormwater Management Plan. The narrative mentions using 0.5 in/hr in one pond, #1SE (only pond where infiltration bench is shown), and states this rate is assumed as a “conservative” rate. The P8 model uses 1.0 in/hr instead of 0.5 in/hr. The HydroCAD modeling has infiltration in all the ponds in the development instead of just pond #1SE. The rate of 0.5 in/hr is not very conservative especially for the soils in the upper 24 ft – 29 ft (boring ST-2 and ST-3, within the basin). Water table readings indicate a high water table may exist, although the readings between borings are inconsistent (possibly perched system). There is one (1) point infiltration testing result showing 4.32 in/hr. One reading alone is not sufficient for accurate infiltration estimating nor is it good practice (more samples are needed) and the infiltration method and results need additional review.

3. Stormwater Routing Using New Outlet – The new outlet is lower than the existing outlet under 30th St., but it is not clear what the downstream elevations and capacities are to ensure the new outlet is feasible, nor are details of the connection given.

Discussion: The most downstream pond and one influencing HWLs on the other development ponds is pond 1SE. Pond 1SE has a listed NWL of 911.0, which is almost two feet below the existing culvert invert of 912.8 under 30th St. Details are needed on the new outlet for pond 1SE shown in the southeast corner (invert, size, type of pipe, permissions off-site, downstream conveyance elevations and capacity, etc.). No tailwater is used in the model for pond 1SE and this assumption should be verified. Provide information on the downstream conveyance to ensure that elevation and capacity exists for the proposed flows (186 or 331 cfs-? for 100-yr rainfall event) and associated calculated HWLs.

4. Stormwater Modeling – The information provided in the summary and modeling are inconsistent and details on where the upstream flow values originate from are lacking, making evaluation of flow routing difficult.

Discussion: The model should be updated to better represent what is happening hydrologically in the system. Provide information on where the Existing Conditions peak flow rates come from and how they were derived. Comparing proposed peak flow rates to existing conditions is difficult without context on the existing flow rates – and the capacity of the system downstream to convey that flow. Show how and where upstream flows (2-yr 100 cfs, 10-yr 172 cfs, and 100-yr 331 cfs per Report Summary) will come into the site. Which values for incoming flows is correct, the Runoff Comparison table or the HydroCAD modeling, since they are factor of ~2X different (e.g., table 2-yr = 100 cfs, model 2-yr = 54 cfs)? The only inlet to pond 1SE is a 15” storm sewer in the northeast corner. Pipe size and inverts need to be shown for the proposed new outlet for pond 1SE (the regional flow path). Pipe sizes and inverts should also be labeled on the

grading plans. As noted above, no tailwater is shown in the model for pond 1SE and this assumption should be verified with downstream information.

5. Include Associated Improvements – Accounting for localized road improvements are not included.

Discussion: If there are road improvements planned (development-specific) on city or county roads for access to the development (e.g., turn lanes, by-pass lanes, etc.), that additional runoff should also be accounted for in the analysis and sizing.

6. Flood protection – Surface Emergency Overflows (EOFs) are not shown or provided below critical building/home elevations.

Discussion: All building lowest floors should be 2 feet above the 100-yr high water level or 1 foot above the overland emergency overflows (EOFs), whichever is greater. Show all EOFs on the plans and show the potential inundated areas if the pipes were blocked, since it appears many of the home elevations do not satisfy 1 foot above the emergency overflow. Emergency overflows should be provided for all low points and ponds. The lowest building opening should be set at a minimum of 1' above the EOF. The preference is to adjust some of the grading to provide an overland overflow, but as an alternative we would consider installing a secondary (separate) EOF pipe from the ponds. The pipe would be set at or slightly higher than the HWL of the pond and should be sized adequately large enough to be considered non-clogging (36" minimum). Street low points should have an EOF that limits ponding/flooding depth to a maximum of 2' in order to allow emergency access to all properties. With EOFs issue addressed, there are still proposed homes with their lowest floor not meeting the 100-yr HWL + 2' freeboard standard, including: Block 1 lot 1; Block 7 lot 1; and Block 8 lots 1, 15, 16, 17.

7. Pond Configurations – Various aspects of pond configurations (maintenance access and relation to infiltration bench, infiltration design, and narrow portion for conveyance) need to be addressed and could impact future city maintenance.

Discussion: Pond access for maintenance (20' minimum width and maximum grade of 10%) should be shown for all facilities including access to inlet and outlet structures on the grading plans. For pond 1SE with the infiltration bench, how would access and maintenance be accomplished without impacting or destroying the infiltration BMP? Provide infiltration bench and infiltration area construction details for how the BMPs will connect to porous materials at depth. There is a narrow, shallow spot in pond 1SE, which conveys regional flows, that could be susceptible to filling with cattails and obstructing flow and should be modified to avoid a restriction. Pond configuration should be reviewed by a city maintenance staff.

8. Pond Water Depths and Long-Term Levels – Pond depths exceed the city standard of 10' maximum and uncertainty about water levels in pond 1SE along Manning Ave. raise some concerns.

Discussion: Details on the pond configuration and construction are needed before the ponds can be accepted. Ponds 1SE and 2SE are proposed to be 13' and 12' deep respectively, exceeding the maximum depth of 10' and should be reduced. A water budget should be performed for pond 1SE to determine if the proposed water levels will be acceptable for the city (safety, maintenance, aesthetics, etc.).

9. Pond Side Slopes – Review pond side slopes for maintenance.

Discussion: State the maximum slopes on ponds, specifically 1SE, on the grading plans. Notes on sheet GP1 mention maximum of 4:1 slopes, but grading plans appear steeper than that. Slopes greater than 3:1 typically are not allowed, and depending on where water levels stabilize, this also impacts the appropriate slopes and where 10:1 safety benches are appropriate.

10. Spring Runoff – Review if spring snowmelt would impact the design.

Discussion: Depending on the final configuration of the regional flow system, determine if a spring snowmelt critical event should be evaluated in the design.

11. Drawdown Time – Demonstrate 48 hour drawdown is accomplished with regional flows.

Discussion: Provide draw down time analysis in the infiltration basins. The drawdown requirement is 48 hours. These facilities appear to be on-line and would be subject to the regional flows from upstream, potentially impacting the draw down time.

12. Water Quality Report – Correct water quality value in table.

Discussion: The Stormwater Report table Provided TP Removal Efficiencies (%) lists a value of 97.9% removal of TP which does not appear to match the model output so it should be updated.

13. Landscaping Plan – The provided landscape plan is incomplete for infiltration areas.

Discussion: Provide landscaping plan and details for the infiltration areas. Seeding only of infiltration areas should be avoided; use at least 50% coverage of plugs for the plantings to enhance establishment. An alternative to seed mix 250, with invasive species such as smooth brome, should be used, except possibly in roadside areas.

Other Considerations:

14. The VBWD should quantify and address the downstream flooding and/or water quality implications of the proposed development and increased runoff.
15. Coordination with VBWD on maximum bounce in the infiltration BMPs should be addressed since pond and infiltration area 1SE show a bounce of 4.5 feet for 100-yr event, exceeding VBWD's maximum bounce of 1.5 feet.
16. Erosion and sediment control, once planning/design approach has been finalized, should be reviewed for protection of ponding and infiltration areas and downstream areas.

Not all aspects of the submittal were reviewed. Additional items may arise as final design is reviewed. Please let us know if you have questions regarding the comments.

Station #1
3510 Laverne Ave. No.
Lake Elmo, MN 55042
651-770-5006



Station #2
4259 Jamaca Ave. No.
Lake Elmo, MN. 55042
651-779-8882

LAKE ELMO FIRE DEPARTMENT

August 27, 2014

After review of the PRELIMINARY PLAT – VILLAGE PARK RESERVE, the following are items that will need to be addressed, moving forward:

- **ROADWAYS**
 - Street naming and numbering per city ordinance.

- **FIRE HYDRANTS**
 - Spacing/Location, it appears there are some that may be closer than the 500' spacing required and could be eliminated. Locate on corners of intersections to gain the most benefit from hydrants.

Reviewed by

Greg Malmquist, Fire Chief

"Proudly Serving Neighbors & Friends"



Public Works Department

Donald J. Theisen, P.E.
Director

Wayne H. Sandberg, P.E.
Deputy Director/County Engineer

September 3, 2014

Nick Johnson
City Planner
City of Lake Elmo
3600 Laverne Avenue North
Lake Elmo, MN 55042

RE: Washington County comments on the preliminary plat for the Village Park Preserve in the City of Lake Elmo

Dear Mr. Johnson,

Thank you for providing the County with the concept plan of the Village Preserve South subdivision in Section 19, Township 29, Range 20, City of Lake Elmo. The project will consist of 104 single family residential lots on 63.6 acres. Based on review of the plans, we offer the following comments and recommendations to consider as you process this subdivision application through the City of Lake Elmo:

- The proposed access point on 30th Street is acceptable to the County. A collector roadway is identified in the center of the subdivision that will connect 30th Street to Trunk Highway (TH) 5 through the Easton Village subdivision.
- The Functional Classification of CSAH 15/ Manning Avenue is "A" Minor Arterial Roadway, expander category. The future right-of-way requirement within this section of roadway is 184 feet. As part of the subdivision plat, there should be an additional 42 feet of right-of-way dedicated to Washington County. This will need to be verified prior to final plat. There also needs to be additional right-of-way at the 30th and CSAH 15/Manning Avenue intersection since this is programmed for a traffic signal and additional turn lanes in the future. Traffic staff will review the plan and provide comments directly to the city engineer.
- A Right of Way Permit will be required for any work in the CSAH 15/Manning Avenue right-of-way as it relates to the development. A plan set is required with the application and include any grading, installation of culverts, installation of water and sewer services, left and right turn lanes on CSAH 15/Manning Avenue, signage, landscaping, and any other improvements within county right-of-way.
- The proposed project will generate pedestrian/bicycle traffic on CSAH 15/ Manning Avenue so pedestrians from the future development will need to access any future off road trail. The future trail along CSAH 15/Manning Avenue will be constructed as part of the CSAH 15/Manning Avenue project.
- The developer or the city must submit the drainage report and calculations to our office for review of any downstream impacts to the county drainage system. Along with the drainage calculations, we will request written conclusions that the

Village Preserve South
September 3, 2014

volume and rate of stormwater run-off into the county right-of way will not increase as part of the project. Stormwater drainage and future drainage easements along Manning Avenue are being coordinated with the Manning Avenue Project.


As the developer plans the stormwater facilities on this property, there should be consideration for setbacks from county right-of-way and perimeter landscape elements and berming.

- Access control must be dedicated to Washington County along the CSAH 15/Manning Avenue.
- Washington County's policy is to assist local governments in promoting compatibility between land use and highways. Residential uses located adjacent to highways often result in complaints about traffic noise. Traffic noise from this highway could exceed noise standards established by the Minnesota Pollution Control Agency (MPCA), the U.S. Department of Housing and Urban Development, and the U.S. Department of Transportation. Minnesota Rule 7030.0030 states that municipalities are responsible for taking all reasonable measures to prevent land use activities listed in the MPCA's Noise Area Classification (NAC) where the establishment of the land use would result in violations of established noise standards. Minnesota Statute 116.07, Subpart 2a exempts County Roads and County State Aid Highways from noise thresholds.

County policy regarding development adjacent to existing highways prohibits the expenditure of highway funds for noise mitigation measures in such areas. The developer should assess the noise situation and take any action outside of County right of way deemed necessary to minimize the impact of any highway noise.

If you have any questions or comments to the responses on the Village Preserve concept plan, please contact me at Ann.pung-terwedo@co.washington.mn.us.

Sincerely,



Ann Pung-Terwedo
Senior Planner

C. Carol Hanson, Office Specialist

R/Plat Reviews/City of Lake Elmo/Village Preserve South

METROPOLITAN AIRPORTS COMMISSION

Minneapolis-Saint Paul International Airport

6040 - 28th Avenue South • Minneapolis, MN 55450-2799

Phone (612) 726-8100



September 3, 2014

Mr. Nick Johnson
City Planner
City of Lake Elmo
3800 Laverne Avenue North
Lake Elmo, MN 55042-9629

Re: Village Park Preserve Preliminary Plat Review
Lake Elmo Airport

SENT VIA EMAIL

Dear Mr. Johnson:

As requested in your Land Use Review package dated August 26, 2014, the Metropolitan Airports Commission (MAC) has reviewed the Village Park Preserve Preliminary Plat that will be presented to the Lake Elmo Plan Commission on September 8, 2014. We appreciate the opportunity to review the document, and offer the following comments.

Aircraft Over Flights and Noise

The proposed Village Park Preserve development is located adjacent to the Lake Elmo Airport in an area that receives aircraft overflights. Although the Baseline Year 2005 and Forecast Year 2025 65 DNL Noise Contours do not appear to encompass any of the proposed residential parcels, the eastern portion of the property is located in close proximity to the Forecast 65 DNL Noise Contour line. (Residential development should not occur within the 65 DNL Noise Contour.) It is the MAC's experience that placing residential areas in such locations around airports can result in noise complaints and resident concerns about aircraft noise. The MAC requests that prospective property buyers within the proposed Village Park Preserve development be provided information on the properties' locations relative to the Lake Elmo Airport and the related existence of aircraft operations over this area.

Water Quality – Surface Water Runoff

The Village Park Preserve Preliminary Plat provides some information about the location of proposed storm water ponds for the development area. As outlined in previous review comments provided for the adjacent Easton Village Concept Plan and Preliminary Plat, open water ponds, especially those with mowed grass nearby, have been shown to be hazardous to the flight of aircraft due to the use of the ponds by Canada geese and other waterfowl. The FAA's Advisory Circular 150/5200-33B, *Hazardous Wildlife Attractants On or Near Airports*, can be found on the agency's web page via the following link.

http://www.faa.gov/documentLibrary/media/advisory_circular/150-5200-33B/150_5200_33b.pdf

The Metropolitan Airports Commission is an alternative action employer.
www.mspairport.com

Rebert Airport • AIRLAKI • ANOKA COUNTY/BLAINE • CRYSTAL • FLYING CLOUD • LAKE ELMO • SAINT PAUL/DOWN TOWN

This Advisory Circular outlines the restrictions and prohibitions surrounding drainage areas within the vicinity of airports as well as guidelines for not only ponds, but other potential wildlife attracting sources. According to the circular, the entire development area under consideration lies within the separation distance recommended by the FAA (5,000 feet for airports serving piston-powered aircraft).

The MAC fully supports the use of infiltration basins in the vicinity of the Lake Elmo Airport, and encourages all ponding areas to be designed as dry ponds that are non-attractive to waterfowl. If this is not possible, we offer the following suggestions to reduce the attraction to wildlife: design ponds with no slope benches; maintain a water depth of less than two feet so that water-emergent growth can occur; plant tall grasses around ponds; install riprap around ponds; and/or cover ponds with a grid of kevlar wire to keep birds out. Based on the Grading Plan included in the Preliminary Plat, the normal water depth in all of the proposed stormwater ponds appears to exceed the recommended two feet. We are concerned that these ponds are being proposed as open water retention facilities, and request that infiltration basins be designed instead. Please provide additional information about the design of the stormwater ponds, including the outfall elevations, proposed water release rates, and measures that will be taken to reduce the attractiveness of the ponds to waterfowl. At the time of the Final Plat, we will object to the use of open water retention ponds that do not incorporate appropriate waterfowl mitigation features. Finally, please identify who will be the responsible party for long-term maintenance of these ponds.

Airspace

Due to the proximity of this proposed development to the Lake Elmo Airport, we request that the applicant file an aeronautical study with the Federal Aviation Administration (FAA) for any structure or object, including temporary construction equipment, which will exceed a height of 35 feet above the ground within this development area and provide a copy of the study results to the MAC prior to the commencement of construction activities. Additional information about the process to file an aeronautical study with the FAA can be found on the agency's Obstruction Evaluation/Airport Airspace Analysis website via the following link.

<https://oeaaa.faa.gov/oeaaa/external/portal.jsp>

Street Luminaries

Due to the close proximity of the proposed development to the runways at the Lake Elmo Airport, we request the street luminaries be down-lighted to avoid confusion by pilots as they approach the airfield at night.

Landscaping

The Preliminary Landscaping Plan indicates that a mixture of deciduous and evergreen trees will be planted along the south and east sides of Stormwater Pond #1SE. We are concerned that the trees closest to the approach surface for Runway 4 could one day grow to become an obstruction to the Airport's airspace and impact flight procedures. In addition, fruits borne by these trees (if any) may attract wildlife. We request that vegetation in this area be limited to

Mr. Nick Johnson
September 3, 2014
Page 3


shrubs and tall grasses. The City must also be aware that any of the trees planted in the vicinity of an approach surface may require removal at some future date if they become an obstruction to the airspace of the Airport and compromise flight procedures.

Construction Measures

Please ensure that the contractor is required to develop and implement a dust control plan that will prevent airborne particulates generated during construction from interfering with aircraft operations at the Lake Elmo Airport.

Thank you for the opportunity to comment on the Village Park Preserve Preliminary Plat. The Lake Elmo Airport is an important recreational and transportation asset to the City and the region. If you have any questions, please contact me at 612-726-8129 or via e-mail at neil.raiston@mspmac.org.

Sincerely,



Neil Raiston, A.A.E.
Airport Planner

cc: Bridget Rief, MAC
Chad Leque, MAC
Joe Harris, MAC
Patrick Mosites, MAC



VILLAGE PARK PRESERVE (PARCEL E) DESIGN REVIEW REPORT **LAKE ELMO, MN**

LANDSCAPE ARCHITECTURAL DESIGN REVIEW DATED SEPTEMBER 4TH, 2014

REVIEWED PLAN SET DATED AUGUST 8TH, 2014

Required Action Items by Village Park Preserve Project Landscape Architect

1. Provide your calculations for street frontage trees on sheet LP1.
2. Please represent planting areas within centers of Cul-de-sacs.
3. Provide temporary and permanent groundcover vegetation utilizing 100% native landscape plants for all lots, commonly held HOA & City R.O.W. areas with the exception of the areas noted to be sodded, irrigated and managed as traditional turf bed areas. Suggested native cover for proposed home lots could be Little Bluestem with the addition of some (10+ species) native wildflowers depending on aesthetic look desired (all blue flowers, mix of flowering times, etc...). Suggested permanent native cover should provide the most appropriate ecologically correct mixes. A suggested example would be to reference the seed mixes offered by MN Native Landscapes (<http://www.mnnativelandscapes.com/>). Please provide the appropriate mix for each specific proposed landscape situation. For example the short dry upland mix for a non-irrigated upland outlot area where shorter grasses are desired adjacent to paths or streets.
4. Provide landscape irrigation plans for all commonly held HOA & City R.O.W. areas.
5. We would encourage the use of some native understory shrubs & flowering trees (clump or single stem) to add aesthetic interest and promote pollinator & wildlife food/habitat. Also, other native trees such as quaking aspen and tamarack would also be encouraged in a variety of sizes to replicate a natural planting pattern.

SINCERELY,

LANDSCAPE ARCHITECTURE, INC.

STEPHEN MASTEY, ASLA, CLARB, LEED AP BD+C
DIRECTOR OF DESIGN