CONTRACT CHANGE ORDER FORM

CITY OF LAKE ELMO, MINNESOTA LAKE ELMO AVE SEWER INFRASTRUCTURE IMPROVEMENTS

FOCUS ENGINEERING, inc.

2013.123	IVIENTS				
CHANGE ORDER NO. 4 DATE:			February 5, 2014		
TO: Minger Construction , Inc. 2471 Galpin Court, Suite 110, Chanhassen, MN 55317					
This Document will become a supplement to the Contract and all provisions will apply hereto. The Contract Documents are modified as follows upon execution of this Change Order.					
CHANGE ORDER DESCRIPTION / JUSTIFICATION:					
This change order is being issued to import an additional 699 CY of fill to address grading changes required along the lift station access roadway located at Lisbon Avenue. The additional fill material was needed to protect from freezing an existing 4-inch sewer service pipe from the Elmo View Townhomes by maintaining the existing cover and insulating around the pipe. This design change addresses a change in field conditions discovered during construction of the lift station access roadway. The elevation of the 4-inch gravity sewer service pipe to the existing city-owned drainfield was discovered to be too shallow at approximately 3.5 feet in depth. Attachments (list documents supporting change): Revised Plan Sheets C105 & C517					
ITEM DESCRIPTION OF PAY ITEM	UNIT	QTY	UNITE PRICE	INCREASE/(DECREASE)	
CO4-1 ADDITIONAL FILL & GRADING AT LIFT STATION SITE	CY	699	\$8.66	\$6,053.34	
NET CONTRACT CHANGE \$6,053.				\$6,053.34	
Sum of Additions/Deductions approved to date (CO # 1 and # 2) \$ (10,533.7 Contract Amount to date \$ 3,452,667.9 Amount of this Change Order (ADD) (DEDUCT) (NO CHANGE) \$ 6,053.3			3,463,201.60 (10,533.70) 3,452,667.90 6,053.34 3,458,721.24		
The Contract Period for Completion will be (UNCHANGED) (INCREASED) (DECREASED) days					
ENGINEER 0 BY 1-28-Z014 DATE DATE			APPROVED BY CONTRACTOR BY 1-28-2014 DATE		
APPROVED BY OWNER: CITY OF LAKE ELMO, MINNESOTA					
ВУ	ВУ				
DATE	DA	ΓE			