



NOTES:

1. CLEAR AND GRUB TREES AS NECESSARY.
2. CONSTRUCT 1714 SF OF DRAINFIELD.
3. CONSTRUCT 512 LF OF 2-1/2" SCH. 40 FORCEMAIN (PRESSURE SEWER).
4. REMOVE EXISTING SEPTIC TANKS AND DRYWELLS AS REQUIRED FOR NEW CONSTRUCTION.
5. CONNECT TO EXISTING BUILDING SEWER OR SEPTIC TANK AND INSTALL NEW SEPTIC TANK AND PUMP STATIONS AS SHOWN.
6. RESTORE TURF OVER DRAINFIELD AND IN RIGHT-OF-WAY BY SEEDING. ALL OTHER TURF RESTORATION BY SODDING.
7. RESTORE STREET WITH 6" GRAVEL BASE AND 3" BITUMINOUS SURFACE. RESTORE GRAVEL DRIVEWAY WITH 6" GRAVEL BASE.

LAKE JANE
10 YR. FLOOD
EL. 923.90



	1-26-88	JTE	RECORD DRAWING
NO	DATE	BY	DESCRIPTION
REVISIONS			

DESIGNED	DRAWN
LDB	DLW
CHECKED	
LDB	

I HEREBY CERTIFY THAT THIS PLAN WAS PREPARED
BY ME OR UNDER MY DIRECT SUPERVISION AND THAT
I AM A DULY REGISTERED PROFESSIONAL ENGINEER
UNDER THE LAWS OF THE STATE OF MINNESOTA

Larry D Behren

DATE 11-19-84 REG. NO. 12120

TKDA

ENGINEERS ARCHITECTS PLANNERS

TOLTZ, KING, DUVALL, ANDERSON
AND ASSOCIATES INCORPORATED

SAINT PAUL, MINNESOTA

WASTEWATER FACILITIES IMPROVEMENTS
LAKE ELMO, MINNESOTA
E.P.A. PROJECT NO. C 271411

TRI-LAKES
REMOTE D

SHEET NO. 13 OF 16 SHEETS

COMMISSION NO
3064